

The Fire Marshal's Office of Moore, Norman and The University of Oklahoma will be enforcing the adopted 2018 International Fire Code, which will affect mobile food preparation vehicles. Mobile food preparation vehicle inspections will follow all of the requirements in the 2018 International Fire Codes:

Chapter 3- Section 319 Mobile Food Preparation Vehicles

Chapter 31- Section 3106 Outdoor Assembly Events

Some of the deficiencies found from the required codes are:

- LP-gas alarms will be required mounted between 4 and 20 inches from the floor and within 5 feet of the LP-gas cooking components.
- A CO "sniffer"/detector to detect CO levels inside while operating.
- A minimum 2A rated ABC fire extinguisher AND K-class fire extinguisher with proper, current annual inspection (green) tags on each.
- You will need the Cleveland County Health Department to sign off on your permit before we do
- Operations that produce grease-laden vapors will require installing an exhaust hood protected by an automatic fire extinguishing system. As of Feb 1, 2024, you will have to have one in order to operate.
- Mobile or temporary cooking operation shall be separated from buildings or structures, combustible materials, vehicles and other cooking operations by 10'
- Use of Generators
 - Exhaust properly ventilated up and away from people, buildings and other cooking operations
 - Located a safe distance away from people, buildings and other cooking operations
 - Extension cords must be in good condition, sized for the correct use, not a trip hazard and not pinched at entry point into food truck
 - Safe location of the fuel and safe refueling practices
- All electrical and fuel components must meet code

If you have any questions please contact:

Norman Fire Department
Prevention Division
405-307-7104
405-217-7768