



Wastewater Flow Monitoring & Modeling Report

FINAL REPORT | May 2018

Norman Utilities Authority City of Norman, OK



Joel R. Cantwell
5/31/2018



in association with:
RJN Group, Inc.
Veux & Associates, Inc.



Wastewater Flow Monitoring and Modeling Report

FINAL Report

Norman Utilities Authority

City of Norman
May 2018



Contents

1	Introduction.....	1-1
1.1	Background	1-1
1.2	Purpose	1-1
1.3	Report Organization	1-1
2	Collection System Model Development	2-1
2.1	Wastewater Collection System Description	2-1
2.1.1	Previous Studies	2-1
2.1.2	Existing Collection System	2-1
2.1.3	Future Service Areas.....	2-1
2.2	Flow Monitoring	2-4
2.3	Model Physical Development.....	2-4
2.3.1	Previous Model.....	2-4
2.3.2	Physical Development.....	2-4
2.3.3	Sewer Basin Topology	2-6
2.4	Wastewater Loading.....	2-6
2.4.1	City Provided Density Data	2-6
2.4.2	Unit Count Method	2-7
2.4.3	Acreage Method	2-7
2.4.4	City Assumptions for Data Set Development.....	2-8
2.4.5	Adjusted Density Data.....	2-9
2.4.6	Wastewater Loading.....	2-9
2.5	Model Flow Components.....	2-10
2.5.1	Sanitary Flow.....	2-10
2.5.2	Average and Discrete Flows	2-12
2.5.3	Base Wastewater Flow (BWF).....	2-14
2.5.4	Groundwater Infiltration (GWI)	2-15
2.5.5	Rainfall-Dependent Infiltration and Inflow (RDII).....	2-18
2.5.6	Peaking Flow	2-21
2.6	Calibration	2-21
2.6.1	Dry Weather Flow.....	2-21
2.6.2	Wet Weather Flows	2-25
3	Collection System Capacity Analysis	3-1
3.1	System Analysis Criteria	3-1
3.1.1	Sewer Infrastructure	3-1
3.1.2	Service Areas	3-1
3.1.3	FBO 2030 Loading Scenario.....	3-1

3.1.4	Design Storm Event	3-3
3.1.5	Capacity Criteria.....	3-3
3.1.6	Major System Improvements	3-3
3.2	System Capacity	3-4
3.2.1	Existing System Overall Flow.....	3-4
3.2.2	Dry Weather Flow Analysis	3-4
3.2.3	Wet Weather Flow Analysis	3-6
3.3	I/I Reduction Efficiency Analysis	3-11
3.3.1	Background	3-11
3.3.2	RDII Calibration Comparison	3-11
3.4	Conclusions.....	3-12
4	Collection System Scenario Analysis	4-1
4.1	Introduction.....	4-1
4.2	Evaluation Criteria	4-1
4.2.1	Sewer and Lift Station Capacity	4-1
4.2.2	Interceptor Sizing	4-1
4.2.3	Force Main Sizing.....	4-2
4.2.4	WRF Design Flow	4-2
4.2.5	Cost Estimating Criteria for Gravity Piping.....	4-3
4.2.6	Cost Estimating Criteria for Lift Stations and Force Mains	4-5
4.3	One-Plant Scenario	4-5
4.3.1	Pipeline Evaluation.....	4-5
4.3.2	Lift Station and Force Main Evaluation	4-31
4.3.3	Estimated Construction Costs.....	4-34
4.3.4	Norman WRF Design Flow	4-35
4.4	Two-Plant Scenario	4-37
4.4.1	Pipeline System Evaluation.....	4-37
4.4.2	Lift Station and Force Main Evaluation	4-45
4.4.3	Estimated Construction Costs.....	4-45
4.4.4	Norman WRF and North WRF Design Flows	4-45
5	Evaluation Results Summary.....	5-1
5.1	Effectiveness of Recent Improvements.....	5-1
5.2	Recommended Future Collection System Improvements for Full Build-Out 2030 Flows	5-1

Tables

Table 2-1. Residential Unit Density for CUSA	2-7
Table 2-2. Land Use Unity Density for Non-residential CUSA and FUSA.....	2-8
Table 2-3. Land-use Based Wastewater Loading.....	2-10
Table 2-4. Average and Discrete Flows from Flow Monitoring Data	2-13
Table 2-5. Groundwater Infiltration Analysis.....	2-15
Table 2-6. RDII Hydrograph Parameters	2-20
Table 2-7: Uncalibrated Dry Weather Flow Comparison	2-22
Table 2-8. Calibrated Dry Weather Flow Comparison	2-23
Table 2-9. Calibrated Wet Weather Flow Comparison	2-26
Table 3-1. FBO 2030 Flow Summary	3-4
Table 3-2. Peak DWF Capacity Issues at FBO 2030	3-6
Table 3-3. Design Storm Capacity Issues at FBO 2030	3-9
Table 3-4. R-Value Comparison of Current Model to Previous Model	3-12
Table 4-1. Estimated Unit Construction Costs for Wastewater Interceptors (2014 Dollars).....	4-4
Table 4-2. Bishop Sewer basin Proposed Piping Improvements.....	4-11
Table 4-3. Brookhaven Sewer Basin Proposed Piping Improvements.....	4-14
Table 4-4. Imhoff Sewer Basin Proposed Piping Improvements	4-16
Table 4-5. Lift Station D Sewer Basin Proposed Piping Improvements ¹	4-19
Table 4-6. Normandy Sewer Basin Proposed Piping Improvements	4-23
Table 4-7. Tecumseh Sewer Basin Proposed Piping Improvements	4-26
Table 4-8. Westside Sewer Basin Proposed Piping Improvements	4-28
Table 4-9. York Sewer Basin Proposed Piping Improvements.....	4-30
Table 4-10. Existing Lift Station Model Conditions	4-31
Table 4-11. Existing Lift Station and Force Main Capacity Evaluation	4-32
Table 4-12. Estimated Gravity System Improvement Costs for the One-Plant Scenario	4-34
Table 4-13. Predicted Norman WRF Wastewater Flows for One-Plant Scenario	4-35
Table 4-14. Design Storm Capacity Issues at FBO 2030 – Two-Plant Scenario	4-41
Table 4-15. Comparison of Gravity Piping Improvements Between One-Plant and Two-Plant Scenarios.....	4-44
Table 4-16. Estimated Gravity System Improvement Costs for the Two-Plant Scenario ¹	4-45
Table 4-17. Difference in Improvement Costs Between One-Plant and Two-Plant Scenarios	4-45
Table 4-18. Predicted WRF Wastewater for Two-Plant Scenario.....	4-46
Table 5-1. Summary Comparison of One-Plant and Two-Plant Scenario Evaluation Results	5-1

Figures

Figure 2-1. Existing Wastewater Collection System	2-2
Figure 2-2. Wastewater Service Basins	2-3
Figure 2-3. Modeled Collection System	2-5
Figure 2-4. Wastewater Discharge Sources	2-11
Figure 2-5. Flow Component Illustration	2-11
Figure 2-6. Typical Residential Diurnal Flow Pattern.....	2-14
Figure 2-7. Hydrologic Features	2-17
Figure 2-8. Example RTK Hydrograph.....	2-19
Figure 3-1. Wastewater Service Areas	3-2
Figure 3-2. 5-year, 4-hour Storm Hyetograph.....	3-3
Figure 3-3. Peak DWF Capacity Issues at FBO 2030	3-5
Figure 3-4. Wet Weather Event Capacity Issues at FBO 2030	3-7
Figure 4-1. FBO 2030 Dry Weather Flow	4-2
Figure 4-2. Estimated Unit Construction Costs for Wastewater Interceptors (2014 Dollars)	4-4
Figure 4-3. Recommended Piping Improvements – One-Plant Scenario.....	4-6
Figure 4-4A. Bishop Sewer Basin Proposed Piping Improvements	4-7
Figure 4-4B. Bishop Sewer Basin Proposed Piping Improvements	4-8
Figure 4-4C. Bishop Sewer Basin Proposed Piping Improvements	4-8
Figure 4-5. Bishop Sewer Basin Proposed Manhole Improvement Location	4-9
Figure 4-6. Brookhaven Sewer Basin Proposed Piping Improvements.....	4-13
Figure 4-7. Imhoff Sewer Basin Proposed Piping Improvements	4-15
Figure 4-8A. Lift Station D Sewer Basin Proposed Piping Improvements	4-17
Figure 4-8B. Lift Station D Sewer Basin Proposed Piping Improvements	4-18
Figure 4-9A. Normandy Sewer Basin Proposed Piping Improvements.....	4-21
Figure 4-9B. Normandy Sewer Basin Proposed Piping Improvements.....	4-22
Figure 4-10. Tecumseh Sewer Basin Proposed Piping Improvements	4-25
Figure 4-11. Westside Sewer Basin Proposed Piping Improvements	4-27
Figure 4-12. York Sewer Basin Proposed Piping Improvements.....	4-29
Figure 4-13. Predicted Norman WRF Flow Curve for One-Plant Scenario for Peak 2-Hour FBO 2030	4-36
Figure 4-14. Design Storm Capacity Issues at FBO 2030 – Two-Plant Scenario	4-39
Figure 4-15. Recommended Piping Improvements – Two-Plant Scenario.....	4-43
Figure 4-16. Gravity Piping Improvements in Bishop Creek Basin Not Needed for Two-Plant Scenario	4-44
Figure 4-17. Predicted Norman WRF and North WRF Flow Curves for Two-Plant Scenario for Peak 2-Hour FBO 2030	4-46

Appendices

Appendix 2A: Flow Meter Sub-Basin Contribution

Appendix 2B: Dry Weather Diurnal Flow Patterns

Appendix 2C: Dry Weather Hydrographs

Appendix 2D: Wet Weather Hydrographs

Appendix 3A: Node Model Output for FBO 2030 Design Storm Applied to Existing System

Appendix 3B: Conduit Model Output for FBO 2030 Design Storm Applied to Existing System

Appendix 4A: Wastewater Flow Analysis

Appendix 4B: 2001 Master Plan Planning Capacity Excerpt

Appendix 4C: Cost Adjustment from 2007 to 2014

Appendix 4D: Conduit Model Output for One-Plant Scenario Improvements

Appendix 4E: Conduit Model Output for Two-Plant Scenario Improvements



This page is intentionally left blank.

1 Introduction

1.1 Background

Norman's wastewater collection system consists of gravity interceptors and collectors, lift stations, and force mains that convey all wastewater to the existing Norman Water Reclamation Facility (WRF) on the south side of the city for treatment and discharge to the Canadian River. Norman (City) is a growing and thriving community, and as the area served by the system increases in area and population density, the ability of the collection system to adequately collect and convey the resulting wastewater flows is challenged.

In 2001, the City completed a wastewater master plan which recommended improvements to the collection system to convey predicted future flows. Most of the recommended projects have been constructed. Additionally, the master plan recommended a second WRF in the northern part of the City to serve the areas which flow by gravity to the north but are currently pumped to the south. The decision on whether or not to construct the second WRF in the future has not been made to date.

1.2 Purpose

The purpose of the Wastewater Flow Monitoring and Modeling Report is three-fold:

- Conduct updated flow monitoring and modeling of the system to determine the effectiveness of the collection system improvements that have been implemented since the last planning process.
- Determine additional collection system improvements that need to be implemented to handle future build-out flows considering updated land use designations, future service areas, and population projections.
- Determine an alternative set of additional collection system improvements that would need to be made to handle future flows if the City constructs a new WRF on the northern side of the City.

1.3 Report Organization

This *Wastewater Flow Monitoring and Modeling Report* contains the following content:

- Chapter 2 describes the existing collection system and the development and calibration of an updated hydraulic model.
- Chapter 3 documents the hydraulic modeling analysis of the collection system to determine effectiveness of recent recommended capital improvements and remaining discrepancies that need to be addressed.



- Chapter 4 presents locations, sizes, and estimated costs of additional recommended collection system improvements for two scenarios: 1) continuing to rely on the existing WRF to treat all wastewater or 2) constructing a new WRF to serve the northern side of the City.
- Chapter 5 summarizes the results.

2 Collection System Model Development

The purpose of this chapter is to describe the process used to construct the collection system model including the network update, load allocation and calibration conducted to develop the model to a level of completeness for performing the analyses required.

2.1 Wastewater Collection System Description

2.1.1 Previous Studies

The most recent study of the City of Norman's (City's) wastewater collection system was conducted by Camp Dresser & McKee and is documented in the *Wastewater Master Plan (Master Plan)* dated September 2001. Several refinements have been made to the *Master Plan* recommendations since its completion, and the paragraphs below present the most current information on the existing collection system, future service areas, and proposed improvements as they relate to this Project.

According to past wastewater modeling efforts, the full build-out of the *Norman 2025 Land Use and Transportation Plan (Norman 2025 Plan)* will result in a total average daily flow of 21.5 mgd, including 17.0 mgd in the south service basins and 4.5 mgd in the north service basins. These values are termed the Full Build-Out Flows.


2.1.2 Existing Collection System

Figure 2-1 shows the sewer basins, gravity mains, force mains, and lift stations of the existing system as of May 30, 2010. The entire system is served by the Norman Water Reclamation Facility (WRF) located at the south end of the City.

The red line on **Figure 2-1** represents the geographic boundary between sewersheds that naturally flow to the north and those that naturally flow to the south. The areas to the north of the boundary are currently serviced by lift stations, which pump the wastewater over the ridgeline and into the south gravity system. Including all areas with existing sewer service and those to which the City is obligated to provide service, the average daily wastewater flow to the existing WRF, according to the *Master Plan*, is 13.9 million gallons per day (mgd), which includes the contribution from the developed, vacant final platted and vacant preliminary platted areas as of August 2000.

2.1.3 Future Service Areas

The *Norman 2025 Plan* defines 16 Future Service Areas (FSAs), which are wastewater service basins where service is not currently provided but will be needed for future development. As shown on **Figure 2-2**, eight of the FSAs are located north of the flow division boundary while the other eight are located to the south. As part of the *Norman 2025 Plan*, wastewater collection infrastructure will be constructed in the FSAs to serve the full build-out of those areas. For the work associated with this project, the City has also identified future extensions. These are areas of potential extensions to the identified FSAs in the *Norman 2025 Plan*.




LEGEND

- Active Lift Station
- Flow Division Line
- Force Main
- Gravity Main
- Street Centerlines
- Sewer Sub-basins


SOURCE: CITY OF NORMAN

**CITY OF NORMAN
FLOW MONITORING AND MODELING
EXISTING WASTEWATER COLLECTION SYSTEM
(AS OF 2010)**



HDR HDR ENGINEERING, INC.
17111 PRESTON RD, SUITE 300
DALLAS, TX 75248-1232
972-960-4400

FIGURE 2-1



BASIN KEY



ALAMEDA PARK (AP)	IMHOFF (IM)	SUMMIT LAKES (SL)
ASHTON GROVE (AG)	LIFT STATION D (LD)	SUMMIT VALLEY (SV)
BISHOP (BS)	NORMANDY (NY)	SUTTON PLACE (SP)
BROOKHAVEN (BH)	PARK HILL (PH)	TECUMSEH (TC)
EAGLE CLIFF (EC)	POST OAK (PO)	VO-TECH (VT)
EAST RIDGE (ER)	ROYAL OAKS (RO)	WESTSIDE (WS)
HALL PARK (HP)	SIENA SPRINGS (SS)	YORK (YK)

LEGEND

- FLOW DIVISION LINE
- SEWER SUB-BASIN
- FUTURE SERVICE BASIN (NORMAN 2025 PLAN)
- POTENTIAL FUTURE SERVICE BASIN EXTENSION
- STREET CENTERLINE

SOURCE: CITY OF NORMAN

**CITY OF NORMAN
FLOW MONITORING & MODELING
WASTEWATER SERVICE BASINS**



HDR HDR ENGINEERING, INC.
17111 PRESTON RD, SUITE 300
DALLAS, TX 75248-1232
972-960-4400

FIGURE 2-2

FILE: J:\MAP_Docs\IMXD\2005 PROJECT\PT139\45_FIGURE1-2_WASTEWATERSERVICEBASINS_8X11.MXD

2.2 Flow Monitoring

Flow monitoring for the project was conducted by the RJN Group (RJN). The flow monitoring report was submitted by RJN in November 2010 under separate cover. The collection system was divided into 32 sub-basins for the purposes of flow monitoring with an average of 83,300 linear feet of pipe per sub-basin. Thirty-two (32) continuously recording flow meters and ten (10) rain gauges were installed.

The original flow monitoring period was from May 1, 2010, through August 1, 2010. Due to a lack of rainfall events, the flow monitoring period was extended. Flow monitoring was terminated on September 15, 2010, after the large rainfall event from Tropical Storm Hermine was captured on September 7-9. The total flow monitoring period was 135 days (4 and a half months).

RJN processed the data and balanced the readings by basin to provide consistent data. Hydrographs were prepared for each sub-basin for subsequent use in model development and calibration.

2.3 Model Physical Development


2.3.1 Previous Model

The City had a skeleton version of the collection system in the MIKE SWMM model platform by DHI software. In order to evaluate the capacity of the existing wastewater collection system, perform scenarios as part of the project scope, and to establish a tool for planning future expansion, a hydraulic model has been created using the InfoWorks™ software, developed by Innovyze. InfoWorks™ is a commercially available program that uses an integrated visual display to present system information and to report hydraulic capacity. The model was originally developed and utilized in InfoWorks™ CS Version 16.5.1 and then later converted to InfoWorks™ ICM 6.5.8 upon Innovyze's announcement that CS would no longer be supported.

2.3.2 Physical Development

The model was developed to account for pipes of 10-inch diameter or larger in the City's system. Where connectivity was necessary, smaller diameter pipes were included. In essence, laterals and mains are not included. Collectors taking flow from sub-basins and the trunk lines conveying to the Norman WRF are included. The City has a total of 11,339 pipe segments; the section of pipe between manhole nodes. Of these, 4,012 segments are included in the model, or 35%. Of 462 total miles of pipe, approximately 189 miles are included in the model, or 41%. The infrastructure included in the InfoWorks™ model is shown on **Figure 2-3**.

FILE: J:\MAP_DOC\SMXD\2005 PROJECT\PT139\45_FIGURE1-3_MODELEDCOLLECTIONSYSTEM_8X11.MXD




LEGEND

- MODELED MANHOLE
- ▲ LIFT STATION
- ▲ INACTIVE LIFT STATION
- FORCE MAIN
- GRAVITY MAIN
- FLOW DIVISION LINE
- SEWER SUB-BASIN
- STREET CENTERLINE

SOURCE: CITY OF NORMAN

CITY OF NORMAN
FLOW MONITORING & MODELING
 MODELED COLLECTION SYSTEM



HDR HDR ENGINEERING, INC.
 17111 PRESTON RD, SUITE 300
 DALLAS, TX 75248-1232
 972-960-4400

FIGURE 2-3

All Graphical Information System (GIS) electronic files were provided by City staff, including base maps, sewer basin boundaries, gravity pipes, force mains, land use and population data. The City also provided lift station data, pump curves when available, as-built information, and other corresponding data. These files provide the input data required to construct the model. Because the GIS files were available, there was no advantage to converting the skeleton model in the MIKE SWMM platform to InfoWorks™. The model was solely developed from the GIS files and data provided by the City as part of this work.

Connectivity was established for each pipe segment between upstream and downstream manholes. While manhole inverts were provided through GIS attribute data, manual manipulation was required to reassign inverts that were incorrect or missing information. This step was an iterative process, working with City staff to resolve all connectivity issues.

2.3.3 Sewer Basin Topology

The City has identified 21 sewer basins, divided further into 140 sub-basins, as shown on **Figure 2-2**. The City used the sub-basins to generate existing and future populations, as described below. HDR created a topology for the sewer basins to correct gaps or overlapping polygons in the GIS data that was provided. Any gaps or overlaps identified were manually corrected. Utilizing the flow monitoring data for the sewer basins, HDR was able to determine flow characteristics including sub-basin groundwater infiltration and rainfall-dependent infiltration and inflow.

2.4 Wastewater Loading

2.4.1 City Provided Density Data

The City provided data sets, reflective as of May 31, 2010, to be used for the wastewater loading in the model for the following service areas:

- Current Urban Service Area (CUSA)
 - Developed
 - Vacant Final Platted
 - Vacant Preliminary Platted
 - Vacant Unplatted
- Future Urban Service Area (FUSA)
 - Norman 2025 Plan Future Areas
 - Potential Future Extensions to Norman 2025 Plan

A land use approach was used for developing the model loading using the data sets. A combination of reviewing unit counts for residential land use and using acreage was

used to develop the loading for the model, as further described below. The average wastewater demand provided by the City is 85 gallons per capita per day (gpcpd).

2.4.2 Unit Count Method

For the CUSA, with the exception of the vacant unplatted service area, the City determined the number of residential units and associated acreage for each residential land use type per sewer sub-basin. Unit densities contained in the data set are listed in **Table 2-1**. The unit counts were multiplied by the unit densities for each residential land use type to give a residential population per sub-basin. The residential population per sub-basin divided by the residential acreage for the sub-basin provides a demand density in persons/acre. For each sub-basin, the residential demand density was applied to parcels assigned with a residential land use. The residential demand density multiplied by the parcel acreage multiplied by 85 gpcpd provided the wastewater load contribution from that parcel. The wastewater load contribution was assigned to the nearest manhole in the model.

Table 2-1. Residential Unit Density for CUSA

Land Use Type	Unit Density (persons/unit count) ¹
Low Density Residential (LDR)	2.55
Medium Density Residential (MDR) [2-4 units]	1.96
MDR (mobile home park)	2.56
High Density Residential (HDR) [5 or more]	1.87
Nursing Home	1.00

¹Data Source: US Census Bureau/American Community Survey (ACS) 5-Year Estimates 2006-2010 and the City of Norman Planning Department

2.4.3 Acreage Method

For non-residential land use in CUSA, all land uses in the vacant unplatted CUSA, all land uses in FUSA, and all land uses in FUSA extensions, the City determined the amount of acreage per land use type per sewer sub-basin. Unit densities contained in the data set are listed in **Table 2-2**. For each land use type, per sub-basin, the acreages were multiplied by the unit and summed to give a population per sub-basin. The population per sub-basin divided by the acreage for the sub-basin provides a demand density in persons/acre for each land use type. For each sub-basin, the demand density was applied to matching parcel land use type in the model. The demand density multiplied by the parcel acreage multiplied by 85 gpcpd provided the wastewater load contribution from that parcel. The wastewater load contribution was assigned to the nearest manhole in the model.

Table 2-2. Land Use Unity Density for Non-residential CUSA and FUSA

Land Use Type	Unit Density (persons/acre) ¹
Low Density Residential (LDR)	8.87
Medium Density Residential (MDR)	13.17
High Density Residential (HDR)	28.44
Commercial	5.00
Office	5.00
Industrial	10.00
Institutional	7.00
Mixed Use (Municipal)	14.38
Very Low Density Residential (VLDR)	1.275
Commercial – Residential (CR)	0.255

¹Data Source: US Census Bureau/American Community Survey (ACS) 5-Year Estimates 2006-2010 and the City of Norman Planning Department

2.4.4 City Assumptions for Data Set Development

The following statements of understanding and assumptions were used by the City when developing the data sets:

1. Hotels loaded as commercial. Nursing homes and assisted living centers loaded as medium density residential (MDR) or high density residential (HDR) based on density using bed counts and parcel acreage. Dorms and hospitals loaded as institutional (no individual bed counts or occupancy rates were included for these areas).
2. Floodplain acreages were adjusted in the following ways, according to Development Status:
 - a. For developed areas, floodplain was recoded to the primary land use of the parcel unless the parcel was a park or open space, in which case the floodplain was left alone.
 - b. For vacant final platted, vacant preliminary platted, and vacant unplatted properties the floodplain was not adjusted, so that the amount of available developable land would not be artificially increased by the floodplain acreage. Future Areas include floodplain acreages as indicated in the *Norman 2025 Plan* and the latest FEMA maps.
3. House counts: Structures layer (2007) was supplemented by the inclusion of permitted structures from January 2005 through December 2009.
4. Aerial Photography used throughout this process was taken in March 2010.
5. Norman 2025 CUSA and FUSA are reflected as of May 31, 2010. Potential extensions to FUSA identified as of May 31, 2010.

6. Structures and parcel layers are reflected as of May 31, 2010.
7. Acreages highlighted in yellow in the data spreadsheet were adjusted to allow certain areas to be counted by total developed lots rather than by acreage. Acreages highlighted in green indicate where acreages were re-added to the table to reflect true total acreage for the sub-basin.
8. Population calculated using US Census Bureau/American Community Survey (ACS) 5-Year Estimates 2006-2010. Additional residential and mixed use population calculations from the *Norman 2025 Plan* were provided by the City of Norman Planning Department.

2.4.5 Adjusted Density Data

After review of the data sets, HDR adjusted the population and density within several sub-basins to be more accurately reflected in the model. The adjustments made include:

- **Acreage Adjustment per Sub-Basin:** The residential density land use categories were compared against the given land use acreage. If a residential land use category was assigned unit counts but not acreage, the unit counts were reallocated to a residential land use category that had acreage assigned. The population and density were then recalculated, effectively increasing the population. Since the model required population and density based loading, and not unit counts, this conversion was required.
- **Nursing Homes:** Unit or bed counts were provided for nursing homes. However, when determining population for the sub-basin, the nursing homes were included in the high density residential total. This skews the loading in the model. To more accurately model the nursing home load contribution, HDR identified the location of the nursing homes, removed the population from the high density land use category and applied the density directly to the parcel as a point load. The density for the high density land use category was recalculated and applied in the model.
- **Norman Housing Authority:** The City included land owned by the Norman Housing Authority in the Nursing Home land use category. For simplicity and due to its similarities, the loading was allocated in the model as high density residential.

The reallocation was verified in two ways. First, a revised density calculation was made and compared to the City provided density to make sure the value was not significantly skewed. Second, the total population using the reallocated load was compared to the original data set total population. The percent difference calculated was less than 0.5% for each case (1.5% total), validating the reallocation.

2.4.6 Wastewater Loading

Table 2-3 presents the wastewater loading that is used as the baseline condition in the model (base model file). The wastewater loading was applied on a sub-basin basis in the model; however, due to the large number of sub-basins, the wastewater loading data shown in **Table 2-3** has been summarized per sewer basin for the report discussion.

Table 2-3. Land-use Based Wastewater Loading

Sewer Basin	Land Use Based Load Totals for Developed CUSA ¹ (mgd)				
	Residential ²	Commercial	Industrial	Institutional	TOTAL
Lift Station D	0.56	0.01	0.07	0.05	0.70
Park Hill	0.02	0.00	0.00	0.00	0.02
Tecumseh	0.00	0.00	0.08	0.00	0.08
Vo-Tech	0.00	0.00	0.00	0.02	0.02
York	0.00	0.00	0.09	0.04	0.13
Subtotal North Basins	0.58	0.01	0.24	0.12	0.95
Alameda Park	0.00	0.00	0.00	0.00	0.00
Ashton Grove	0.10	0.00	0.00	0.00	0.10
Bishop	3.13	0.11	0.16	0.36	3.77
Brookhaven	1.06	0.09	0.04	0.04	1.23
Eagle Cliff	0.01	0.00	0.00	0.00	0.01
East Ridge	0.08	0.00	0.00	0.00	0.08
Hall Park	0.09	0.00	0.00	0.00	0.09
Imhoff	2.51	0.08	0.06	0.22	2.88
Normandy	0.24	0.09	0.02	0.02	0.36
Post Oak	0.00	0.00	0.00	0.00	0.00
Royal Oaks	0.10	0.00	0.00	0.00	0.10
Siena Springs	0.00	0.00	0.00	0.00	0.00
Summit Lakes	0.01	0.00	0.00	0.00	0.01
Summit Valley	0.01	0.00	0.00	0.00	0.01
Sutton Place	0.03	0.00	0.00	0.00	0.03
Westside	0.40	0.02	0.00	0.04	0.46
Subtotal South Basins	7.77	0.39	0.29	0.68	9.14
Total All Basins	8.94	0.42	0.76	0.92	11.04

¹Includes the developed platted lots only. Vacant lots are included in the FBO load allocation.


²Residential load includes all residential categories, mobile home parks, and nursing homes.

2.5 Model Flow Components

2.5.1 Sanitary Flow

The total flow in a sanitary sewer system originates from several different sources. Wastewater discharges from municipal sources typically comprise the majority of the total load. Other sources of flow include infiltration of groundwater and inflow from storm events, often referred to together as I&I. Most of the City’s wastewater discharge comes from sources designated as residential land use, as shown in **Figure 2-4**.


Figure 2-4. Wastewater Discharge Sources



From May 1 to September 15, 2010, flow monitoring was conducted by the RJN Group (RJN) for the purpose of measuring dry weather and wet weather flow from the sewer basins. Results of the flow monitoring are presented under separate cover in the *Wastewater Flow Monitoring Report* (RJN, November 2010). **Appendix 2A** contains a table listing the flow meters and the sub-basins that contributed to each flow meter.

The flow metering data was analyzed to determine base wastewater flow (BWF), groundwater infiltration (GWI), and rainfall dependent infiltration and inflow (RDII) in order to perform model calibration. The flow components are illustrated on **Figure 2-5**.

Figure 2-5. Flow Component Illustration



2.5.2 Average and Discrete Flows

Average flows were calculated based on evaluating dry weekday days observed in the flow meter data and taking an average value of the measured flow over the monitoring period. Discrete flows for each metered sewer basin were calculated based by taking the average dry weather flow at each meter and subtracting the upstream metered flows. Therefore, discrete flows indicate the characteristics of the individual sewer basin at a given meter location. The calculated average discrete flows are summarized in **Table 2-4**. In some instances, including BP-20 and BP-24, the discrete basin flows were calculated to be negative. Likely sources of error include flow transfers via bypass piping near the flow monitor locations, timing delays, and timestep differences between the meters and not the actual contribution of that basin.




Table 2-4. Average and Discrete Flows from Flow Monitoring Data

Flow Monitor	Average Daily Flow (mgd)	Discrete Basin Average Daily Flow (mgd)
BH-02	1.99	0.28
BH-03	0.31	0.31
BH-04	1.40	0.56
BH-05	0.83	0.51
BH-06	0.32	0.11
BH-07	0.21	0.21
BP-17	2.82	0.24
BP-18	0.58	0.23
BP-17/18 Combined	3.40	0.46
BP-19	0.65	0.65
BP-20	0.11	-0.20
BP-21	1.82	0.67
BP-22	0.32	0.32
BP-23	1.14	0.59
BP-24	0.35	-0.21
BP-25	2.10	1.53
BP-26	0.57	0.57
BP-27	0.56	0.56
BP-28	0.37	0.37
BP-29	0.13	0.13
IH-12	0.61	0.40
IH-13	0.20	0.20
IH-14	1.13	0.32
IH-15	0.81	0.44
IH-16	0.38	0.38
ND-08	0.69	0.36
ND-09	0.34	0.34
WC-30	0.52	0.29
WC-31	0.23	0.23
WC-32	0.03	0.03
WS-01	2.88	0.20
WS-10	0.73	0.12
WS-11	1.63	0.50
Total All Basins		10.88

2.5.3 Base Wastewater Flow (BWF)

Base wastewater flow originates from residential, commercial, industrial, and institutional facilities and are discharged into the sewer system. Unlike infiltration, which enters the collection system at a constant rate throughout the day, BWF typically exhibits a diurnal flow pattern similar to the one shown in **Figure 2-6**.

Figure 2-6. Typical Residential Diurnal Flow Pattern



Diurnal flow patterns were developed for each land use category by evaluating the flow monitoring data, water usage of the top 25 water users in the service area, and typical industry standards for the given land use types. A residential diurnal flow pattern was assigned in the model to all parcels with a residential, mobile home park and nursing home land use designation; a commercial diurnal flow pattern was assigned in the model to all parcels with commercial land use designations, and so forth. An exception to this methodology was made to three industrial sites that are listed within the top 25 water users of the service area. Information about flow contribution, shift work and water usage was obtained from the City which allowed site specific diurnal flow patterns to be developed allowing for a more accurate representation of this loading in the model.

Appendix 2B contains the diurnal flow patterns developed for the land use categories that are applied in the model.

2.5.4 Groundwater Infiltration (GWI)

Groundwater infiltration is defined as the constant inflow of ground water into the collection system irrespective of rainfall availability. This value is determined by several factors including the location of the groundwater table and the overall physical condition of the collection system. Furthermore, GWI can also be impacted by periods of wet and dry weather conditions.

For wastewater collection systems, such as Norman, that do not typically experience substantial industrial and/or commercial flows throughout a given 24-hour period, GWI is equated to collection system minimum flows that occur during the late night and early morning hours as measured by the flow monitors. Several factors, including the presence of high groundwater, proximity to lakes and streams, and the predominant land use within each sewer basin help to determine if these flows are indicative of groundwater flow. The data is summarized in **Table 2-5**. **Figure 2-7** illustrates the relationship of sewer basins to stream locations.

Table 2-5. Groundwater Infiltration Analysis

Flow Monitor	Discrete Average Daily Flow (mgd)	Groundwater Infiltration (mgd)	Percent of Discrete Average Daily Flow	Predominant Land Use	Probability of High Groundwater or Proximity to Lakes or Streams ¹
BH-02	0.28	0.10	36%	Residential	Low to Moderate
BH-03	0.31	0.03	10%	Residential	Low
BH-04	0.56	0.27	49%	Commercial	Low to Moderate
BH-05	0.51	0.17	33%	Residential	Low to Moderate
BH-06	0.11	0.04	31%	Residential	Low
BH-07	0.21	0.04	17%	Industrial	Low to Moderate
BP-17	0.24	0.22	92%	Institutional	Low
BP-18	0.23	0.22	98%	Institutional	Low
BP-17/18 Combined	0.46	0.44	95%	Institutional	Low
BP-19	0.65	0.26	41%	Institutional	Low to Moderate
BP-202	-0.20	-0.06	32%	Residential	Low
BP-21	0.67	0.30	44%	Residential	Low
BP-22	0.32	0.09	28%	Residential	Low
BP-23	0.59	0.08	13%	Residential	Low
BP-242	-0.21	0.00	0%	Residential	Low
BP-25	1.53	0.60	39%	Residential	Low
BP-26	0.57	0.35	61%	Residential	Low
BP-27	0.56	0.15	27%	Residential	Low
BP-28	0.37	0.16	43%	Residential	Low
BP-29	0.13	0.02	18%	Residential	Low




Flow Monitor	Discrete Average Daily Flow (mgd)	Groundwater Infiltration (mgd)	Percent of Discrete Average Daily Flow	Predominant Land Use	Probability of High Groundwater or Proximity to Lakes or Streams ¹
IH-12	0.40	0.13	32%	Residential	Low
IH-13	0.20	0.07	37%	Residential	Low
IH-14	0.32	0.07	20%	Residential	Low
IH-15	0.44	0.28	64%	Industrial	Low
IH-16	0.38	0.05	14%	Residential	Low
ND-08	0.36	0.16	44%	Residential	Moderate to High
ND-09	0.34	0.12	37%	Residential	Low
WC-30	0.29	0.10	34%	Residential	Moderate to High
WC-31	0.23	0.07	31%	Residential	Low
WC-32	0.03	0.00	17%	Residential	Low
WS-013	0.20	-0.40		Residential	Low
WS-10	0.12	0.11	92%	Institutional	Low
WS-11	0.50	0.60	121%	Residential	Low
Total All Basins	10.88	4.85			

¹Qualitative review only based on Figure 2-7 and calculation of flood plain acreage by basin.


²Discrete minimum flows could not be effectively determined based on likely impacts from bypass piping and flow routing.

³WS-01 is the flow monitor that received all flow from the western portion of the system. Due to the large volume of upstream flow at this meter, local flows, particularly groundwater infiltration, could not be determined.



FILE: J:\MAP_DOC\SMXD\2005 PROJECT\PT139\45_FIGURE1-7_HYDROLOGICFEATURES_8X11.MXD

CITY OF NORMAN
FLOW MONITORING & MODELING
 HYDROLOGIC FEATURES



NORMAN
 UTILITIES
 AUTHORITY



HDR ENGINEERING, INC.
 17111 PRESTON RD, SUITE 300
 DALLAS, TX 75248-1232
 972-960-4400

2.5.5 Rainfall-Dependent Infiltration and Inflow (RDII)

Rainfall-dependent infiltration and inflow represents the total wet weather flow that enters the collection system in the form of inflow and infiltration.

- Inflow is water that enters the sewer system relatively quickly after a wet weather event begins and recedes quickly once the rain event ends. It occurs through unintended pathways such as depressed manhole covers, holes in manhole covers, down spouts connected to the system, cross connections, etc.
- Infiltration occurs when water that is contained in the soil enters the pipe through leaking joints, damaged pipe sections, or poor connections to manholes. Infiltration typically continues well past the end of a wet weather event.


The RTK unit hydrograph method is used to derive the RDII response of the sewer system based on the collected rainfall and flow monitoring data. This method is based on fitting three triangular unit hydrographs to an actual RDII hydrograph derived from the flow meter data. R, T, and K factors are developed for each triangular unit hydrograph and represent the following:

- R is the percentage of rainfall that entered the system within each sewer basin during the monitoring period.
- T, the time of concentration, is the time difference between when the rainfall started and when the peak flow hydrograph was observed at each of the monitoring locations.
- K, the recession coefficient, is the ratio between the peak of the flow hydrograph and the point at which the RDII receded.

The three triangular unit hydrographs are defined as follows, and an example hydrograph is shown in **Figure 2-8**:

- Q₁ represents the initial event response and includes some inflow from sources that are directly connected to the sewer system including roof downspouts, leaking manholes and pipeline cross-connections. T values for this hydrograph are generally on the order of 0.5 to 2 hours.
- Q₂ includes primarily RDII and infiltration, with longer T values, generally from 2.5 to 5 hours.
- Q₃ includes infiltration that occurs long after the event is over and represents a long soaking storm, since infiltration would slowly seep into the collection system. T values for this are generally in the 5 to 10 hour range.

Figure 2-8. Example RTK Hydrograph



Eight rainfall events of greater than 1 inch of rainfall in a 24-hour period were recorded during the flow monitoring period for this project. Ultimately, the rainfall received during the Tropical Storm Hermine event that occurred from September 7-9, 2010, was used to develop the RTK hydrographs for wet weather calibration. This storm was selected due to the intensity of the storm and a duration that was suitable for calibration purposes. Doppler data was obtained to verify rain gauge information for each basin.

RTK hydrographs were developed based on basins containing similar land use breakdowns and included similar percentages of floodplain. The R, T, K factors developed are listed in **Table 2-6**.

Table 2-6. RDII Hydrograph Parameters

Flow Monitor	Initial Inflow Response (Q ₁)			RDII Response (Q ₂)			Post-Storm Infiltration Response (Q ₃)		
	R ₁	T ₁	K ₁	R ₂	T ₂	K ₂	R ₃	T ₃	K ₃
BH-02	0.0016	1.5	0.8	0.0022	4	0.8	0.009	4.5	1.5
BH-03	0.005	0.5	1	0.007	3	2	0.006	7	3
BH-04	0.005	1	1	0.007	1.2	2	0.005	5	2
BH-05	0.003	1.7	1.5	0.0025	3.5	2.5	0.0014	4	3
BH-06	0.0008	1.8	1	0.0004	1.8	2.5	0.0002	3	2
BH-07	0.005	1	1	0.007	1.2	2	0.005	5	2
BP-17	0.003	1.7	1.5	0.0025	3.5	2.5	0.0014	4	3
BP-18	0.003	1.7	1.5	0.0025	3.5	2.5	0.0014	4	3
BP-19	0.003	1.7	1.5	0.0025	3.5	2.5	0.0014	4	3
BP-20	0.003	1.7	1.5	0.0025	3.5	2.5	0.0014	4	3
BP-21	0.0008	1.8	1	0.0004	1.8	2.5	0.0002	3	2
BP-22	0.0008	1.8	1	0.0004	1.8	2.5	0.0002	3	2
BP-23	0.0008	1.8	1	0.0004	1.8	2.5	0.0002	3	2
BP-24	0.003	1.7	1.5	0.0025	3.5	2.5	0.0014	4	3
BP-25	0.003	1.7	1.5	0.0025	3.5	2.5	0.0014	4	3
BP-26	0.003	1.7	1.5	0.0025	3.5	2.5	0.0014	4	3
BP-27	0.003	1.7	1.5	0.0025	3.5	2.5	0.0014	4	3
BP-28	0.003	1.7	1.5	0.0025	3.5	2.5	0.0014	4	3
BP-29	0.0004	0.9	2	0.0009	4	1	0.0005	4.5	1.5
IH-12	0.005	0.5	1	0.007	3	2	0.006	7	3
IH-13	0.0008	1.8	1	0.0004	1.8	2.5	0.0002	3	2
IH-14	0.003	1.7	1.5	0.0025	3.5	2.5	0.0014	4	3
IH-15	0.003	1.7	1.5	0.0025	3.5	2.5	0.0014	4	3
IH-16	0.005	0.5	1	0.007	3	2	0.006	7	3
ND-08	0.0016	1.5	0.8	0.0022	4	0.8	0.009	4.5	1.5
ND-09	0.005	1	1	0.007	1.2	2	0.005	5	2
WC-30	0.0008	1.8	1	0.0004	1.8	2.5	0.0002	3	2
WC-31	0.0016	1.5	0.8	0.0022	4	0.8	0.009	4.5	1.5
WC-32	0.0013	1.5	0.5	0.0013	4.9	2	0.0008	5	5
WS-01	0.005	0.5	1	0.007	3	2	0.006	7	3
WS-10	0.005	0.5	1	0.007	3	2	0.006	7	3
WS-11	0.005	0.5	1	0.007	3	2	0.006	7	3

2.5.6 Peaking Flow

As described above, a flow pattern was determined for each land use type. The flow pattern was assigned to the matching land use type in the system model. As a time-step analysis is performed, the wastewater loading is adjusted for each parcel by the flow factor from the assigned pattern at the given time step. As an example, refer to the residential flow pattern shown in **Figure 2-6**. For example, given a residential parcel, the wastewater loading will be adjusted by 1.6 times at 8:00 a.m., 1.3 times at noon, remain unadjusted at 4:00 p.m., adjusted by 1.25 times at 8:00 p.m., and so forth.

2.6 Calibration

The wastewater model was calibrated for both dry and wet weather flows:

- Dry weather calibration is a process of reducing the amount of error between the wastewater loading (described in Section 2.3) when compared to the BWF component derived by analyzing the flow meter data (described in Section 2.4).
- Wet weather calibration is a process of reducing the amount of error between the flow volume observed when the RTK hydrographs are applied to the sub-basins in the model versus the actual flow volume measured during the wet weather event.

Both are iterative processes to attempt to reduce the amount of error to 10% or less between observed and measured flows.

2.6.1 Dry Weather Flow

Table 2-7 shows the uncalibrated flow comparison between the model and the measured flow monitoring values. There were 27 flow monitoring locations whose modeled percentage of observed flows were outside the $\pm 10\%$ calibration target. These are the raw results comparing the discrete flow monitoring data to the model data (after initial loading but prior to calibration).

Table 2-8 presents the final calibrated results for dry weather flow of the base model achieved by iteratively adjusting the factors in the model. **Appendix 2C** shows the pre-calibration and post-calibration dry weather hydrographs for each flow monitor.



Table 2-7: Uncalibrated Dry Weather Flow Comparison

Flow Monitor	Measured Discrete Daily Flow (mgd)	Modeled Discrete Daily Flow (mgd)	Percent of Measured Discrete Daily Flow (%)
BH-02	0.28	0.21	-25%
BH-03	0.31	0.32	1%
BH-04	0.56	0.40	-30%
BH-05	0.51	0.40	-23%
BH-06	0.11	0.07	-35%
BH-07	0.21	0.14	-31%
BP-17	0.24	0.02	-92%
BP-18	0.23	0.80	257%
BP-19	0.46	0.31	-33%
BP-20	0.65	0.24	-62%
BP-21	-0.20	-0.61	197%
BP-22	0.67	0.46	-32%
BP-23	0.32	0.23	-29%
BP-24	0.59	0.53	-10%
BP-25	-0.21	-0.16	-25%
BP-26	1.53	0.94	-39%
BP-27	0.57	0.38	-34%
BP-28	0.56	0.46	-18%
BP-29	0.37	1.22	232%
IH-12	0.13	0.15	13%
IH-13	0.40	0.30	-25%
IH-14	0.20	0.15	-24%
IH-15	0.32	0.32	0%
IH-16	0.44	0.32	-27%
ND-08	0.38	0.22	-42%
ND-09	0.36	0.16	-55%
WC-30	0.34	0.14	-57%
WC-31	0.29	0.26	-9%
WC-32	0.23	0.26	9%
WS-01	0.03	0.09	224%
WS-10	0.20	0.13	-31%
WS-11	0.12	0.10	-21%



Table 2-8. Calibrated Dry Weather Flow Comparison

Flow Monitor	Measured Discrete Daily Flow (mgd)	Modeled Discrete Daily Flow (mgd)	Percent of Measured Discrete Daily Flow (%)
BH-02	0.28	0.30	6%
BH-03	0.31	0.32	2%
BH-04	0.56	0.60	6%
BH-05	0.51	0.48	-6%
BH-06	0.11	0.10	-12%
BH-07	0.21	0.20	-2%
BP-17	0.24	0.25	5%
BP-18	0.23	0.25	11%
BP-19	0.46	0.50	8%
BP-20	0.65	0.70	8%
BP-21	-0.20	0.00	-100%
BP-22	0.67	0.60	-11%
BP-23	0.32	0.35	10%
BP-24	0.59	0.60	1%
BP-25	-0.21	0.00	-100%
BP-26	1.53	1.54	1%
BP-27	0.57	0.58	2%
BP-28	0.56	0.58	3%
BP-29	0.37	0.41	11%
IH-12	0.13	0.12	-9%
IH-13	0.40	0.41	1%
IH-14	0.20	0.20	-1%
IH-15	0.32	0.32	0%
IH-16	0.44	0.48	10%
ND-08	0.38	0.40	6%
ND-09	0.36	0.34	-4%
WC-30	0.34	0.34	1%
WC-31	0.29	0.31	8%
WC-32	0.23	0.24	2%
WS-01	0.03	0.03	5%
WS-10	0.20	0.21	7%
WS-11	0.12	0.13	6%
Total All Basins	11.21	11.89	6%

The resulting calibration reduced the difference between the model flows and the flow monitoring data; however, by adjusting the upstream flows in the calibration process, the downstream flows did not match as closely as they initially did. This is to be expected with the calibration process; as the upstream flows are more closely matched, the downstream flows are adversely altered.

Possible reasons for the flow monitoring locations that still do not match within the target range after calibration include:

- Since some of the flow monitors had low average daily dry-weather flows (<0.2 mgd), the percent error between the measured and modeled flow appears a lot greater than the volume difference really is.
- The flow monitoring data could have been off as much as $\pm 4\%$ itself due to equipment accuracy. This can make the comparison off from the start. This error is especially possible for flow monitors with low flows.
- The dry-weather period may have not been representative of average dry-weather flows experienced over an entire year. Certain areas of the system may not match as well as others due to the land use composition and percent occupancy at the time of flow monitoring and may have caused the flows to be abnormally low or high during the selected flow monitoring time period.
- Seasonal effects on wastewater flow from groundwater-induced infiltration along creeks and other areas with high groundwater can affect the dry-weather calibration. Since the characterization of the effects of groundwater on the system is largely unknown, for this model the groundwater-induced base infiltration was assigned globally across the system within the sanitary unit flow factors. However, over different seasons and depending on recent storm events, groundwater levels can fluctuate and not be accounted entirely in the unit flow factors.

The WRF influent flow records match within 10% and are lower than the summation of flow monitors, which is expected due to flow attenuation in the system downstream of the contributing flow monitoring locations. The flows are still higher than the recorded flows at the WRF.

The overall difference between model results and temporary flow meter data is considered adequate for this planning study given 1) the conservative nature of the model results compared to WRF influent data 2) the relatively small amount of flow under scrutiny, compared to system total, 3) overall system calibration at the WRF is within standard modeling tolerances, and 4) the majority of the flow monitoring locations are within the calibration target.

2.6.2 Wet Weather Flows

As discussed previously, the RTK method was used to develop wet weather hydrographs to match the measured storm event on September 7-9, 2010. Five RTK hydrographs were developed based on land use and assigned to similar land uses across the service area.

Calibration was achieved by adjusting the infiltration percentage for each land use and slope and width for each sub-basin so that the modeled wet weather response closely approximated the observed wet weather response. **Table 2-9** presents the final calibrated results for wet weather flow of the base model. **Appendix 2D** shows the calibrated wet weather hydrographs for each flow monitor.

Where discrete RDII flows were less than average discrete dry weather flows, or negative in value, RDII was modeled at zero. This primarily occurred in basins with large incoming flows but with a very small contribution to that flow. So while the overall modeled flows corresponded well to the observed data, smaller basins would result in having very little impact to the wet weather flow leaving the basin. And because negative flow cannot be added to the model, the discrete wet weather flow components were modeled as zero. This results in a large difference in measured discrete and modeled discrete flows based on totals. If the negative values are removed, the margin of error is much smaller (2%).



Table 2-9. Calibrated Wet Weather Flow Comparison

Flow Monitor	Measured Discrete RDII Flow (mgd)	Modeled Discrete Peak Wet Weather Flow (mgd)	Percent of Measured Discrete RDII Flow (%)
BH-03	0.08	0.08	0%
BH-04	-0.02	0.00	N/A
BH-05	0.14	0.13	-7%
BH-06	0.00	0.00	0%
BH-07	0.09	0.09	-2%
BP-17	0.95	0.94	-1%
BP-18	-0.09	0.00	N/A
BP-19	0.86	0.85	-1%
BP-20	0.11	0.10	-6%
BP-21	-0.17	0.00	N/A
BP-22	0.44	0.43	-3%
BP-23	0.16	0.16	-2%
BP-24	-0.01	0.00	N/A
BP-25	0.15	0.15	0%
BP-26	-0.28	0.00	N/A
BP-27	0.18	0.19	7%
BP-28	-0.04	0.00	N/A
BP-29	0.06	0.07	20%
IH-12	-0.02	0.00	N/A
IH-13	0.24	0.25	3%
IH-14	-0.01	0.00	N/A
IH-15	0.56	0.52	-8%
IH-16	-0.20	0.00	N/A
ND-08	0.16	0.16	1%
ND-09	-0.11	0.00	N/A
WC-30	0.09	0.09	5%
WC-31	-0.03	0.00	N/A
WC-32	0.07	0.07	0%
WS-01	0.00	0.00	0%
WS-10	0.04	0.04	-2%
WS-11	-0.01	0.00	0%
Total All Basins (with negative values)	3.38	4.31	22%
Total All Basins (without negative values)	4.38	4.31	2%

3 Collection System Capacity Analysis

The purpose of this chapter is to document the collection system capacity analysis and infiltration and inflow (I/I) evaluation. This chapter includes a description of the modeling criteria used, identification of model-predicted overflow locations at full build-out 2030 loading conditions (FBO 2030) and a comparison of modeling results to the previous Wastewater System Master Plan (*Master Plan*, CDM, September 2001) to generally ascertain the effectiveness of I/I reduction based on sewer improvements the City has implemented.

3.1 System Analysis Criteria

3.1.1 Sewer Infrastructure

Chapter 2 describes the land use, service areas, wastewater loading, and infrastructure data (i.e., pipes, manholes, and lift stations) used in model development and calibration. The model includes all pipes with a diameter of 10-inches and larger and was calibrated to the existing sewer system infrastructure reflective of May 2010 to coincide with the flow monitoring period. After the model was successfully calibrated, significant system improvements made since May 2010 were incorporated into the model. This updated model (circa April 2012) was used to conduct the capacity analysis.


3.1.2 Service Areas

As described in Chapter 2, the City has three discrete service areas: the Current Urban Service Area (CUSA), the Future Urban Service Area (FUSA), and the Future Urban Service Area Extensions (FUSA-EXT) which are shown on **Figure 3-1**. The CUSA includes the developed, vacant final platted, vacant preliminary platted, and vacant unplatted areas and is generally serviced with the existing sewer infrastructure. The FUSA includes the *Norman 2025 Plan* future areas which will need new infrastructure to service proposed development. The FUSA-EXT includes potential future extensions beyond the FUSA areas identified in the *Norman 2025 Plan* and will need new infrastructure to support the development.


3.1.3 FBO 2030 Loading Scenario

The FBO 2030 scenario was developed in the InfoWorks CS™ V10.5 model by Innovyze to perform the system capacity analysis. The FBO 2030 scenario represents future wastewater loading corresponding to the full build-out conditions from the CUSA, FUSA, and FUSA-EXT applied to the existing sewer infrastructure, which conveys all flows to the existing Norman Water Reclamation Facility (WRF). By applying the FBO 2030 wastewater load to the model, one can identify the future system capacity constraints corresponding to FBO conditions, as identified by the locations in the existing collection system that exceed capacity (defined below) or overflow onto the ground. For this analysis, no future or proposed infrastructure needs are included.

FILE: J:\MAP_DOC\SMXD\2005 PROJECT\TM_2\PN139145_FIGURE2-1_WASTEWATERSERVICEAREAS_8X11.MXD



CITY OF NORMAN
FLOW MONITORING & MODELING
 WASTEWATER SERVICE AREAS




HDR HDR ENGINEERING, INC.
 17111 PRESTON RD, SUITE 300
 DALLAS, TX 75248-1232
 972-960-4400

FIGURE 3-1

3.1.4 Design Storm Event

A 5-year frequency storm of 4-hour duration was established as the design storm event in the *Master Plan*. The local IDF curve (Zone II IDF curve for Oklahoma), shown in **Figure 3-2**, was used for the design hyetograph in the *Master Plan* and applied to the current modeling work. The total rainfall volume of this storm is 3.33 inches.

Figure 3-2. 5-year, 4-hour Storm Hyetograph



3.1.5 Capacity Criteria

The City’s collection system is designed to allow for surcharging in the manholes to within one foot of the rim elevation during a 5-year, 4-hour storm event. Capacity is defined to be exceeded when the water level is less than one foot from the manhole rim, or a sanitary sewer overflow (SSO) occurs. This capacity criteria is used for both the dry weather flow (DWF) and 5-year, 4-hour design storm wet weather flow (WWF) modeled conditions.

3.1.6 Major System Improvements

In 2012, the City implemented Lift Station D improvements. Lift Station D receives all flow from the north collection system and pumps this flow over the ridgeline to the Bishop Creek (BS) basin. From this point, the wastewater in the collection system flows under gravity flow condition to the existing Norman WRF. An equalization basin was constructed as part of the Lift Station D improvements to provide system storage when the peak flows exceed the pump station capacity of 6 million gallons per day (mgd). Lift Station D is designed to be the headworks to a proposed future North WRF.

With the improvements made at Lift Station D, the following lift stations are now inactive:

- Carrington Lift Station
- York Lift Station
- Industrial Lift Station
- Sutton Place Lift Station

The Vo-Tech Lift Station (LS) and Tecumseh LS are still active; however, the discharge of these stations has been redirected to the Little River Interceptor which flows into Lift Station D.

The capacity analysis was performed including these system improvements.

3.2 System Capacity

3.2.1 Existing System Overall Flow

The overall system flow, as modeled for FBO 2030, is listed in **Table 3-1**.

Table 3-1. FBO 2030 Flow Summary


Location	FBO 2030 Loading Condition	
	Dry Weather Flow (mgd)	Peak 2-hr Wet Weather Flow ¹ (mgd)
Lift Station D	3.2	17.7
Norman WRF	18.6	70.8

¹ 5-Year, 4-hour storm

3.2.2 Dry Weather Flow Analysis


As discussed in Chapter 2, diurnal flow patterns were established for each land use type and applied in the model. The use of these patterns simulates the daily variation of DWF allowing the peak DWF to be determined.

The model was used to predict capacity and SSO issues during peak DWF with the FBO 2030 loading applied to the existing sewer system. Three manholes were identified as having a maximum water level in the manhole less than 1 foot from the manhole rim. Of these 3 locations, none were predicted to be an SSO. **Table 3-2** lists these locations, and **Figure 3-3** illustrates the manhole locations in the system.



SOURCE: CITY OF NORMAN

CITY OF NORMAN
FLOW MONITORING AND MODELING
OVERFLOW LOCATIONS
FBO 2030 DRY WEATHER FLOW CONDITION



HDR HDR ENGINEERING, INC.
 17111 PRESTON RD, SUITE 300
 DALLAS, TX 75248-1232
 972-960-4400


FIGURE 3-3

Table 3-2. Peak DWF Capacity Issues at FBO 2030


Map ID	Manhole ID	Rim Elevation	Maximum Water Level Elevation	Freeboard to Manhole Rim (ft)	SSO (Y or N)	Estimated Overflow Quantity (gallons)	Sewer Basin
2	121012	1211.65	1210.68	0.97	N	-	Park Hill
3	162002	1192.00	1191.33	0.67	N	-	Imhoff
4	239042	1136.10	1135.13	0.97	N	-	Normandy
Total Estimated Overflow Quantity						0	

3.2.3 Wet Weather Flow Analysis


Next, the model was run to predict capacity and SSO issues during a 5-year, 4-hour design storm event when the FBO 2030 loading is applied to the existing sewer system. A total of 54 manholes were identified at a maximum water level less than 1 foot from the manhole rim. Of those 54 locations, 21 locations were predicted as SSOs with a total volume of 0.42 million gallons. **Table 3-3** lists these locations, and **Figure 3-4** illustrates the manhole locations in the system. Model results for the FBO 2030 loading at the design storm event for the existing sewer system are provided in **Appendix 3A** (manholes) and **Appendix 3B** (gravity pipe).




INSET 1



INSET 2




INSET 3



CITY OF NORMAN FLOW MONITORING AND MODELING

CAPACITY ISSUE LOCATIONS
ONE PLANT SCENARIO
FBO 2030 5-YEAR 4-HOUR STORM
FLOW CONDITION



MODELED SYSTEM LEGEND

- ▲ Inactive Lift Station
- ▲ Active Lift Station
- <1-FT FREEBOARD
- SSO
- Gravity Main
- WTP Outfall
- Force Main
- Flow Division Line
- City Boundary
- Street Centerlines

SOURCE: CITY OF NORMAN INFRASTRUCTURE AS OF APRIL 2012

INSET MAPS NOT TO SCALE



HDR HDR ENGINEERING, INC.
17111 PRESTON ROAD, SUITE 300
DALLAS, TEXAS 75248-1232
(972) 960-4400

FIGURE 3-4

PATH: C:\USERS\TWHITFIE\DOCUMENTS\WORKING DOCUMENTS\PROJECTS\Active\NORMAN_NORMAN_GISMAP_DOC\MXD\2017_FIGURE_RECREATION\FIGURE3-4.MXD - USER: TWHITFIE - DATE: 10/30/2017

This page intentionally left blank.

Table 3-3. Design Storm Capacity Issues at FBO 2030

Map ID	Sewer Basin	Manhole ID	Rim Elevation	Maximum Water Level Elevation	Freeboard to Manhole Rim (ft)	SSO (Y or N)	Estimated Overflow (gallons)
37	Bishop	243056	1141.00	1141.00	0	Y	6,600
38	Bishop	243088	1138.40	1138.35	-0.05	N	0
39	Bishop	243089	1136.70	1136.42	-0.28	N	0
40	Bishop	260067	1131.16	1130.71	-0.45	N	0
41	Bishop	263037	1208.88	1208.88	0	Y	45,400
50	Bishop	285069	1126.00	1125.31	-0.69	N	0
51	Bishop	297006	1120.81	1120.39	-0.42	N	0
52	Bishop	297007	1120.81	1120.36	-0.45	N	0
53	Bishop	297010	1120.76	1120.10	-0.66	N	0
54	Bishop	321075	1117.42	1117.22	-0.2	N	0
Subtotal Bishop							52,000
6	Brookhaven	72002	1188.24	1188.24	0	Y	42,100
7	Brookhaven	72008	1193.46	1192.55	-0.91	N	0
8	Brookhaven	72024	1193.00	1192.78	-0.23	N	0
10	Brookhaven	98065	1188.19	1188.19	0	N	0
16	Brookhaven	113008	1180.03	1180.03	0	Y	9,600
Subtotal Brookhaven							51,700
23	Imhoff	162002	1192.00	1191.41	-0.59	N	0
42	Imhoff	283037	1152.00	1152.00	0	N	0
43	Imhoff	283118	1144.00	1144.00	0	Y	12,200
44	Imhoff	283125	1151.24	1151.24	0	Y	1,000
45	Imhoff	283128	1148.08	1147.80	-0.28	N	0
46	Imhoff	283129	1147.43	1146.91	-0.52	N	0
47	Imhoff	283130	1146.00	1146.00	0	Y	1,500
48	Imhoff	283131	1145.73	1145.28	-0.45	N	0
49	Imhoff	283132	1145.39	1144.63	-0.76	N	0
Subtotal Imhoff							14,700
9	Lift Station D	76008	1144.00	1143.34	-0.66	N	0
12	Lift Station D	105012	1134.00	1134.00	0	Y	8,200
13	Lift Station D	105014	1128.00	1127.13	-0.87	N	0
14	Lift Station D	105039	1136.50	1136.50	0	Y	7,700
15	Lift Station D	105043	1134.50	1133.62	-0.88	N	0
17	Lift Station D	118008	1158.86	1158.86	0	Y	1,600



Map ID	Sewer Basin	Manhole ID	Rim Elevation	Maximum Water Level Elevation	Freeboard to Manhole Rim (ft)	SSO (Y or N)	Estimated Overflow (gallons)
18	Lift Station D	118015	1162.75	1162.12	-0.63	N	0
19	Lift Station D	119085	1142.46	1142.10	-0.36	N	0
20	Lift Station D	119092	1148.42	1148.42	0	Y	20,500
21	Lift Station D	119093	1150.19	1150.19	0	Y	9,400
Subtotal Lift Station D							47,400
24	Normandy	192020	1147.10	1147.10	0	Y	23,200
25	Normandy	192029	1152.34	1151.83	-0.51	N	0
26	Normandy	192030	1150.16	1149.74	-0.42	N	0
27	Normandy	192031	1148.29	1148.29	0	Y	1,200
28	Normandy	192033	1151.73	1151.73	0	Y	100
29	Normandy	207003	1163.21	1162.36	-0.85	N	0
30	Normandy	207061	1159.05	1158.90	-0.15	N	0
31	Normandy	208022	1157.13	1157.13	0	Y	22,500
32	Normandy	208044	1143.00	1143.00	0	Y	59,300
33	Normandy	208045	1143.92	1143.44	-0.48	N	0
34	Normandy	208072	1142.00	1141.10	-0.9	N	0
35	Normandy	208079	1141.06	1141.06	0	Y	6,700
36	Normandy	239042	1136.10	1135.25	-0.85	N	0
Subtotal Normandy							113,000
22	Park Hill	121012	1211.65	1210.71	-0.94	N	0
Subtotal Park Hill							0
11	Tecumseh	102008	1153.73	1153.26	-0.47	N	0
Subtotal Tecumseh							0
1	York	42006	1168.12	1168.12	0	Y	78,600
2	York	44008	1166.11	1166.11	0	Y	18,300
3	York	44009	1166.99	1166.05	-0.94	N	0
4	York	44010	1166.70	1166.03	-0.67	N	0
5	York	70031	1160.00	1160.00	0	Y	44,700
Subtotal York							141,600
Total North Sewer Shed							189,000
Total South Sewer Shed							231,400
Total All Basins							420,400

3.3 I/I Reduction Efficiency Analysis

3.3.1 Background

To perform the capacity analysis and capital project identification documented in the *Master Plan*, CDM utilized a skeleton version of the collection system model on MIKE URBAN SWMM™ software platform by DHI. Previous flow monitoring data collected in 1998 was used to calibrate the MIKE URBAN SWMM model. While the focus of the capital projects identified in the *Master Plan* was to alleviate SSOs in the system, I/I reduction is also realized when projects are implemented.

The rainfall derived I/I (RDII) analysis performed in 2001, and updated in 2004 by CDM, utilized the same RTK methodology used for the RDII analysis in this modeling effort. The R values (R1, R2, and R3) correspond to the percentage of the RDII that enters the system through direct runoff, intermediate and delayed RDII response. The sum of R1, R2, and R3 is an indicator of the total RDII response. By comparing the sum of R values estimated during the 2004 modeling update and current model calibration, a general system-wide observation can be made regarding effectiveness of I/I reduction in the system as a result of the improvements implemented since the *Master Plan*.

3.3.2 RDII Calibration Comparison

The sewer infrastructure from the two modeling efforts (2004 and the current modeling work) was compared to determine which sewer segments could be identified in both models. Then, the identified sewers were analyzed to determine if the pipe diameter had changed and which sewer basin(s) the sewer serviced. The major basins identified where diameter changes occurred include Lift Station D (formerly identified as Little River in the *Master Plan*), Bishop, Brookhaven, Imhoff and Normandy. The R-value comparison; therefore, focused on these basins.

Some differences that were identified between the two modeling efforts that could affect the difference in rainfall response include:

- Intensity, duration, and antecedent conditions to categorize RDII response may differ widely.
- The *Master Plan* indicates that three storm events captured with the flow monitoring in 1998 were used to perform model calibration; one from April, one from September, and one from November. The flow monitoring for the current project observed two rainfall events which were used to calibrate RDII response in the model; one in June and one in September.
- The reconfiguration of some sewer basins since 2001, including addition/subtraction of land area, impact contributing sewer area characteristics and size, and thus RDII response.
- Flow monitoring locations were different, possibly capturing different system conditions.
- The approaches used in the two models to account for dry-weather infiltration might not be the same.

- The methodology used in the two models to model dry-weather sanitary loading might not be the same. For this modeling work, the CUSA, FUSA and FUSA-EXT loading is as of May 31, 2010. For the 2004 modeling work, the CUSA loading is as of July 1, 2003, the FUSA loading is as of August 2, 2004, and there were no designated FUSA-EXT areas.
- Model extent. The MIKE URBAN SWMM model was more simplified than the InfoWorks CS model, and it used RDII response to simulate both rainfall response and also non-modeled system hydraulics. This would include flow attenuation in RDII response and reduce R1.

However; while being mindful of these limitations, a general conclusion about the reduction of the total rainfall volume entering the system due to implementation of sewer improvements can be derived by the comparison of RDII calibration between the two models. **Table 3-4** compares the weighted sum of R values from the 2004 model to those derived from this flow modeling calibration.

Table 3-4. R-Value Comparison of Current Model to Previous Model

Sewer Basin	2004 Weighted Average Sum of R	2010 Weighted Average Sum of R	Estimated % RDII Reduction
Lift Station D	0.015	0.008	47%
Bishop	0.019	0.005	72%
Brookhaven	0.015	0.012	17%
Imhoff	0.019	0.012	37%
Normandy	0.015	0.015	0%

Three R-values from each major sewer basin, corresponding to direct, intermediate and delayed RDII, from both models were summed and then averaged by overall basin acreage to normalize the results. Based on this comparison, observed RDII in the Norman collection system during the 2010 flow monitoring appears to be lower than that indicated by the data from the 2004 model. The largest difference in R values occurs in the Bishop basin, where the majority of the capital improvements have taken place. No substantial change was indicated for the Normandy basin.

3.4 Conclusions

As stated in the *Master Plan*, a total of 53 SSO locations were identified under the 5-year, 4-hour design storm event resulting in an overflow volume of approximately 8 million gallons (Reference Figure 2-5 in the *Master Plan*). This is based on FBO of the existing, approved and contractual service areas defined in the *Master Plan*.

Under the current FBO 2030 model scenario, which includes FBO loading of the CUSA, FUSA and FUSA-EXT service areas, a total of 22 SSO locations were identified resulting in a total overflow volume of approximately 420,000 gallons. The improvements the City has performed on the collection system since the *Master Plan* have greatly reduced predicted SSO occurrences and volumes. Additional collection system improvements needed to further eliminate SSOs and to convey the FBO 2030 wastewater loading is discussed in the next chapter.

4 Collection System Scenario Analysis

4.1 Introduction

The purpose of this chapter is to document the existing collection system improvements needed to convey FBO 2030 flows without overflows for two alternative wastewater reclamation facility (WRF) planning scenarios. The two planning scenarios include:

- One-Plant Scenario: Conveyance of all wastewater to the existing Norman WRF
- Two-Plant Scenario: Conveyance of the north basin wastewater to a proposed North WRF and conveyance of the south basin wastewater to the existing Norman WRF

Detailed model output is included in the appendices.

In addition, the FBO 2030 design flows and estimated construction costs for each scenario are included in this chapter. The work associated with this project does not include developing or sizing future interceptor or trunk line extensions.

4.2 Evaluation Criteria

4.2.1 Sewer and Lift Station Capacity

The City's collection system capacity criteria allows for surcharging in the manholes to within one foot of the rim elevation during a 5-year, 4-hour storm event. Capacity is defined to be exceeded when the water level is less than one foot from the manhole rim or top of lift station wetwell, or a sanitary sewer overflow (SSO) occurs during the 5-year, 4-hour design storm wet weather flow (WWF) modeled condition.

Using the calibrated model representing the City's physical infrastructure from April 2012, node (manhole and wetwell) locations predicted to overflow under the design 5-year, 4-hour storm event at the FBO 2030 wastewater loading condition were identified and documented in Chapter 3. The same calibrated model used is used in the evaluation of the two planning scenarios documented in this chapter to identify the collection system improvements needed to eliminate the previously identified capacity issues.

4.2.2 Interceptor Sizing

Where needed, interceptors are sized to meet the sewer capacity criteria described above. Whether the interceptor is a replacement or parallel relief sewer is typically based on engineering judgment. The costs of providing a replacement interceptor, for example, can be significant when reviewing construction feasibility and bypass pumping needs for large diameter pipes. In these cases, a parallel relief interceptor resulting in a smaller diameter pipe with less bypass pumping requirements could be more economical.

Generally speaking, pipes that are larger than 18 inches in diameter are usually good candidates for designing relief sewers. This evaluation is typically performed as a cost-saving measure during the design phase of an individual pipeline project.

To be conservative in developing a planning level cost estimate for proposed improvements, it is assumed in this project that pipes will be replaced with a larger diameter pipe rather than paralleled with a relief sewer.

4.2.3 Force Main Sizing


Where needed, force mains are sized to convey the firm pumping capacity required at the lift station with a velocity range of 2 to 7 fps.

4.2.4 WRF Design Flow

The methodology used to determine flow parameters in the *Master Plan* (CDM, 2001) was utilized for this evaluation, as defined below.

Average Dry Weather Flow: Average dry weather flow is determined from the calibrated model based on the FBO 2030 loading applied to the existing sewer infrastructure during a dry weather condition during the seasonal period when the University of Oklahoma is in session. The Norman WRF is modeled as an outfall. There are five main interceptors that convey flow into this outfall. The total of these flows represents the incoming flow to the Norman WRF. **Figure 4-1** illustrates the diurnal curve for an average dry weather flow day from flow from each interceptor and the overall total (labeled as flow totalizer). The predicted average dry weather flow is 17.8 mgd.

Figure 4-1. FBO 2030 Dry Weather Flow



Annual Average Flow: Flow monitoring data was compared to the wastewater treatment plant historical data from the same time period to determine a multiplier for converting Average Dry Weather Flow to Annual Average Flow (included as **Appendix 4A**). The historical data average dry weather flow (from 1993 to 2011) is 10.5 mgd. Plant data during the monitoring period was recorded at an average flow of 11.14 mgd for the three-month period of May, June, and July. Modeled existing dry weather flow was 10.98 mgd, resulting in a multiplier of 1.01. Compared to the annual wastewater flow average at the WRF of 10.8 for the same period, the calculated ratio would be less than 1.0. This is largely due to higher groundwater flows in the summer months during the monitoring. For the purposes of this analysis, the ratio used is 1.01. This results in an Annual Average Flow of 18.0 (17.8 x 1.01).

Planning Capacity: The 5% planning capacity developed during the *Master Plan* is utilized as part of this evaluation. Refer to Section 1.5 of the *Master Plan* for a detailed explanation of how the 5% planning capacity was developed (see **Appendix 4B**).

Maximum Month Flow: The maximum month flow is the largest volume of flow to be received during a continuous 30-day period as predicted by the model under the FBO 2030 loading, wet weather condition. Based on a Maximum Month to Annual Average ratio of 1.2:1, the Maximum Month Flow is 21.6 mgd.

Maximum Day Flow: The maximum day flow is the largest volume of flow to be received during a continuous 24-hour period as predicted by the model under the FBO 2030 loading, wet weather condition. The Maximum Day Flow calculated as 36.0 mgd.

Peak 2-hour Flow: The peak 2-hour flow is the largest volume of flow to be received during a two-hour period as predicted by the model under the FBO 2030 loading, wet weather condition. The Peak 2-hour Flow is calculated as 81.9 mgd.

4.2.5 Cost Estimating Criteria for Gravity Piping

The construction estimates are based on the construction costs presented in Table 3-3 from the *Northside Lift Station Preliminary Engineering Report* (HDR, May 2007). Estimated interceptor costs per linear foot (LF) were developed using cost data from actual bid tabulations at the time the previous report was written. These replacement pipe unit costs are inclusive of all pipeline construction aspects, including mobilization, site work, installation, and overhead and profit. The unit costs from the *Northside Lift Station Preliminary Engineering Report* have been updated from 2007 to 2014 using the *RS Means Construction Cost Indices (CCI) for 1st Quarter 2014*. See **Appendix 4C**. The 2014 estimated unit construction costs for wastewater interceptors are shown in **Table 4-1**.




Table 4-1. Estimated Unit Construction Costs for Wastewater Interceptors (2014 Dollars)

Pipe Diameter (in)	Unit Cost (\$/LF)	Unit Cost (\$/dia-in/LF)
8	\$ 115.93	\$ 14.49
10	\$ 128.26	\$ 12.83
12	\$ 141.83	\$ 11.82
15	\$ 162.79	\$ 10.85
18	\$ 182.53	\$ 10.14
21	\$ 202.26	\$ 9.63
24	\$ 221.99	\$ 9.25
27	\$ 242.96	\$ 9.00
30	\$ 262.69	\$ 8.76
33	\$ 282.42	\$ 8.56
36	\$ 303.39	\$ 8.43
39	\$ 323.12	\$ 8.29
42	\$ 342.86	\$ 8.16
45	\$ 363.82	\$ 8.08
48	\$ 383.55	\$ 7.99
51	\$ 403.29	\$ 7.91
54	\$ 424.25	\$ 7.86
60	\$ 463.72	\$ 7.73
66	\$ 504.42	\$ 7.64
72	\$ 543.88	\$ 7.55

The unit costs listed in **Table 4-1** are shown graphically on **Figure 4-2**. The construction cost per linear foot of interceptor construction increases linearly with increased pipe diameters. The corresponding cost per diameter inch of interceptor per linear foot follows an exponential pattern that is higher for smaller diameter interceptors and decreases for larger diameter pipes.

Figure 4-2. Estimated Unit Construction Costs for Wastewater Interceptors (2014 Dollars)



4.2.6 Cost Estimating Criteria for Lift Stations and Force Mains

Based on recent project experience, the cost estimating criteria used for lift station expansion and force main is:

- \$1,000/gpm of firm pumping capacity required for lift station expansion
- \$8/dia-in/ft for shallow (less than 8 feet) PVC force main installation

4.3 One-Plant Scenario

This section describes the evaluation of the collection system with all flow conveyed to the existing Norman WRF, given the FBO 2030 loading condition under a 5-year, 4-hour storm event.

4.3.1 Pipeline Evaluation


A total of 54 manholes were identified at a maximum water level less than 1 foot from the manhole rim. Of those 54 locations, 22 locations were predicted as SSOs with a total volume of 0.42 million gallons. These locations are shown on **Figure 3-4** and listed in **Table 3-3**.

The locations of the proposed pipeline improvements to eliminate these 54 capacity excursions are shown collectively on **Figure 4-3** and discussed per individual sewer basin below. It is assumed all gravity pipeline improvements are replacement lines for this planning level evaluation. In addition, it is assumed as part of this analysis that sufficient capacity at the headworks of the Norman WRF exists. Wastewater flow entering the WRF is purposely allowed to surcharge. This backwater condition is included in the model at a water surface elevation of 1111.10.

The lift station improvements are discussed in the Lift Station Evaluation section.

The model output data for all conduits (pipe segments) after all the improvements described herein are implemented are included in **Appendix 4D**.

Basin Key		
Sewer Sub-Basins	East Ridge	Siena Springs
BSN_NAME	Hall Park	Summit Lakes
Alameda Park	Imhoff	Summit Valley
Ashton Grove	Lift Station D	Sutton Place
Bishop	Normandy	Tecumseh
Brookhaven	Park Hill	Vo-Tech
Carrington	Post Oak	Westside
Eagle Cliff	Royal Oaks	York



LEGEND


- ▲ Active Lift Station
- ▲ Inactive Lift Station
- Street Centerlines

One-Plant Scenario Improvements

- No Improvements Noted
- New 8"
- New 12"
- New 15"
- New 18"
- New 24"
- New 27"
- New 30"
- New 36"
- New 42"
- New 48"
- New 54"

SOURCE: CITY OF NORMAN; INFRASTRUCTURE AS OF APRIL 2012

CITY OF NORMAN
FLOW MONITORING AND MODELING
 RECOMMENDED PIPING IMPROVEMENTS
 ONE PLANT SCENARIO
 FBO 2030, 5-YEAR 4-HOUR STORM
 FLOW CONDITION



HDR HDR ENGINEERING, INC.
 17111 PRESTON RD, SUITE 300
 DALLAS, TX 75248-1232
 972-960-4400

FIGURE 4-3

PATH: C:\USERS\TWHITFE\DOCUMENTS\WORKING DOCUMENTS\PROJECTS_ACTIVE\NORMAN_NORMAN_GIS\MAP_DOCS\MXD\2017_FIGURE_RECREATION\FIGURE4.3.MXD - USER: TWHITFE - DATE: 11/1/2017


Bishop Sewer Basin

As illustrated on **Figure 3-4**, a total of 10 nodes (manholes) are identified within the Bishop Sewer Basin as having less than 1 foot of freeboard in the manhole. Of these nodes, two are predicted to have an SSO resulting in an approximate overflow quantity of 52,031 gallons under the design storm and FBO 2030 condition.

Approximately 24,223 LF (4.6 mi) of sewer improvements, as shown on **Figure 4-3** and below on **Figures 4-4A, 4-4B, and 4-4C** are identified in order to eliminate the identified nodes and SSO locations to meet the required design criteria previously described.

No lift stations or associated force mains are located within the Bishop Sewer Basin.


Figure 4-4A. Bishop Sewer Basin Proposed Piping Improvements



The individual pipe segments are listed in **Table 4-2**. The information presented includes the pipe ID (with corresponding upstream manhole), Branch ID (corresponding to **Figures 4-4A to 4-4C**) that identifies the grouping, the pipe asset identification number, the existing diameter, the proposed diameter, the peak velocity, the peak flow, and the peak water depth. Peak values represent the maximum value observed during the storm event in the model analysis assuming the piping improvements have been applied.

One manhole, Manhole ID 358001 (shown on **Figure 4-5**), would need to be sealed to contain flow.

Figure 4-5. Bishop Sewer Basin Proposed Manhole Improvement Location





This page intentionally left blank.

Table 4-2. Bishop Sewer basin Proposed Piping Improvements

Pipe ID	Asset ID	Branch ID	Pipe Material	L (ft)	Existing Dia (in)	Proposed Dia (in)	Peak After Improvements		
							Velocity (ft/s)	Flow (mgd)	Water Depth (ft)
286067.1	286067286080	80	UNKN	104	33	36	3.8	15.4	4.5
286080.1	286080296032	80	UNKN	307	33	36	3.8	15.4	3.7
296026.1	296026296046	80	PVC	35	36	36	4.3	15.5	2.8
296027.1	296027296026	80	UNKN	345	33	36	5.1	15.5	2.7
296028.1	296028296027	80	UNKN	303	33	36	4.5	15.5	2.8
296029.1	296029296028	80	UNKN	297	33	36	4.2	15.5	3.0
296030.1	296030296029	80	UNKN	348	33	36	4.2	15.5	3.2
296031.1	296031296030	80	UNKN	356	33	36	4.4	15.4	3.3
296032.1	296032296031	80	UNKN	291	33	36	4.6	15.4	3.2
243055.1	243055243056	182	UNKN	601	18	21	3.3	3.9	2.3
243056.1	243056243057	182	UNKN	560	18	21	2.8	3.4	2.4
329022.1	329022329024	551	FRP	523	48	54	4.1	24.8	5.4
329016.1	329016329017	553	FRP	224	42	48	3.2	20.7	6.2
329017.1	329017329018	553	FRP	417	42	48	3.2	20.7	6.0
329018.1	329018329019	553	FRP	331	42	48	3.2	20.7	5.7
329019.1	329019329020	553	FRP	253	42	48	3.2	20.9	5.6
329020.1	329020329021	553	FRP	561	42	48	3.3	20.9	5.4
329021.1	329021329022	553	FRP	496	42	48	3.9	20.9	5.2
329059.1	329059329016	553	FRP	31	42	48	3.2	20.7	6.4
329023.1	329023329022	554	FRP	95	24	30	1.5	3.1	5.0
329049.1	329049329023	554	PVC	35	24	30	1.4	3.1	5.0
329050.1	329050329049	554	PVC	343	24	30	1.5	3.0	4.8
329051.1	329051329052	554	UNKN	295	18	24	2.4	1.9	2.7
329052.1	329052329053	554	UNKN	350	18	24	2.8	1.9	3.2
329053.1	329053329050	554	UNKN	353	24	30	2.9	2.8	3.9
349001.1	349001329051	554	UNKN	302	12	24	3.2	1.4	2.3
349002.1	349002349001	554	UNKN	207	12	24	2.7	1.4	2.7
349003.1	349003349002	554	UNKN	350	12	24	3.5	1.3	2.6
329010.1	329010329059	560	FRP	362	36	42	2.1	10.1	6.6
321058.1	321058321059	567	UNKN	488	33	36	3.1	11.7	5.2
321059.1	321059321075	567	UNKN	195	33	36	3.2	11.7	5.0
321075.1	321075330021	567	UNKN	161	33	36	3.4	11.7	4.9
329074.1	329074329059	567	DIP	42	36	42	4.4	11.8	4.9
330003.1	330003329074	567	DIP	48	36	42	4.0	11.8	4.9

Pipe ID	Asset ID	Branch ID	Pipe Material	L (ft)	Existing Dia (in)	Proposed Dia (in)	Peak After Improvements		
							Velocity (ft/s)	Flow (mgd)	Water Depth (ft)
297010.1	297010297011	579	UNKN	429	21	27	2.3	3.9	5.2
297011.1	297011297012	579	UNKN	265	21	27	2.5	3.9	4.9
297012.1	297012297013	579	UNKN	201	21	27	3.3	3.9	4.8
297013.1	297013297014	579	UNKN	306	21	27	2.4	3.9	5.0
297014.1	297014297015	579	UNKN	197	21	27	2.7	4.0	4.9
297015.1	297015297022	579	UNKN	307	21	27	3.7	4.0	4.8
297022.1	297022297019	579	UNKN	160	21	27	3.1	4.1	5.2
286092.1	286092286067	609	UNKN	100	33	36	3.8	15.2	4.7
286008.1	286008286054	610	UNKN	492	18	21	4.1	3.2	3.2
286054.1	286054286055	610	UNKN	154	18	21	3.1	3.2	3.5
286055.1	286055286056	610	UNKN	489	18	21	3.1	3.2	3.6
286056.1	286056286082	610	UNKN	407	18	21	2.8	3.2	3.7
286066.1	286066286065	610	UNKN	26	18	21	2.7	3.2	4.7
286082.1	286082286066	610	UNKN	25	18	21	4.9	3.2	4.0
260063.2	260063260067	633	UNKN	343	18	21	2.7	3.1	3.0
260067.1	260067260068	633	UNKN	296	18	21	2.7	3.1	2.9
260068.1	260068260103	633	UNKN	68	18	21	2.8	3.1	2.9
260103.1	260103260104	633	PVC	58	18	21	2.9	3.1	2.8
260104.1	260104260105	633	PVC	323	18	21	2.9	3.1	2.8
260105.1	260105260106	633	PVC	58	18	21	2.7	3.1	2.9
260106.1	260106286010	633	UNKN	215	18	21	3.3	3.1	2.7
286010.1	286010286011	633	UNKN	242	18	21	2.9	3.0	2.9
286011.1	286011286012	633	UNKN	139	18	21	3.2	3.1	2.8
286012.1	286012286013	633	UNKN	448	18	21	3.2	3.0	2.9
286013.1	286013286008	633	UNKN	361	18	21	2.9	3.0	3.1
260014.1	260014260063	654	PVC	21	18	21	3.5	4.2	3.3
244048.1	244048244144	659	UNKN	164	18	21	4.6	3.7	3.1
244144.1	244144260011	659	UNKN	259	18	21	3.6	3.7	3.2
260011.1	260011260012	659	UNKN	494	18	21	3.1	3.7	3.1
260012.1	260012260013	659	UNKN	389	18	21	3.1	3.8	2.6
260013.1	260013260014	659	UNKN	404	18	21	4.5	3.8	2.4
243052.1	243052243059	660	UNKN	138	24	30	4.4	9.5	3.5
243058.1	243058243052	660	UNKN	58	24	30	4.4	9.5	3.8
243059.1	243059243089	660	UNKN	112	24	30	4.5	9.5	3.2

Pipe ID	Asset ID	Branch ID	Pipe Material	L (ft)	Existing Dia (in)	Proposed Dia (in)	Peak After Improvements		
							Velocity (ft/s)	Flow (mgd)	Water Depth (ft)
243060.1	243060243086	660	UNKN	296	24	30	4.7	9.5	2.6
243086.1	243086244143	660	UNKN	134	24	30	4.7	9.5	2.4
243089.1	243089243060	660	UNKN	170	24	30	4.8	9.5	2.7
243057.1	243057243063	675	UNKN	83	18	21	3.2	3.7	1.9
243063.1	243063243064	675	UNKN	200	18	21	4.1	3.7	1.4
243064.1	243064243065	675	UNKN	197	18	21	3.2	3.7	1.6
243065.1	243065244023	675	UNKN	315	18	21	5.0	3.7	0.9
244023.1	244023244025	675	UNKN	38	18	21	5.1	3.7	2.2
244025.1	244025244026	675	VCP	196	18	21	4.9	3.6	3.0
244026.1	244026244047	675	VCP	53	18	21	3.0	3.6	3.6
244047.1	244047244048	675	UNKN	209	18	21	2.9	3.2	3.4
243041.1	243041243083	689	UNKN	134	24	30	4.7	9.4	5.4
243083.1	243083243084	689	UNKN	281	24	30	4.4	9.4	5.2
243084.1	243084243085	689	UNKN	253	24	30	4.3	9.4	5.0
243085.1	243085243087	689	UNKN	78	24	30	4.3	9.4	4.8
243087.1	243087243088	689	UNKN	282	24	30	4.4	9.4	4.4
243088.1	243088243058	689	UNKN	104	24	30	4.4	9.4	4.1
263008.1	263008263009	927	VCP	319	8	12	4.1	1.0	2.6
263009.1	263009263033	927	PVC	290	10	12	2.9	1.1	2.1
263033.1	263033263034	927	PVC	298	10	12	3.1	1.1	1.4
263034.1	263034262082	927	PVC	303	10	12	4.3	1.2	0.6
263037.1	263037263038	959	PVC	112	8	12	3.1	0.9	9.7
263038.1	263038263039	959	PVC	106	8	12	3.1	0.9	9.0
263039.1	263039263040	959	PVC	296	8	12	3.4	0.9	7.3
263040.1	263040263041	959	PVC	367	8	12	3.3	0.9	5.2
263041.1	263041263042	959	PVC	235	8	12	3.2	0.8	4.2
263042.1	263042263043	959	PVC	246	8	12	3.4	0.8	2.6
263043.1	263043263044	959	PVC	119	8	12	3.7	0.8	1.7
263044.1	263044263008	959	PVC	357	8	12	4.3	0.8	0.5

UNKN – information is unknown


Brookhaven Sewer Basin

As illustrated on **Figure 3-4**, a total of 5 nodes are identified within the Brookhaven Sewer Basin as having less than 1 foot of freeboard in the manhole. Of these nodes, 3 are predicted to have an SSO resulting in an approximate overflow quantity of 51,761 gallons under the design storm and FBO 2030 condition.

Approximately 6,607 LF (1.2 mi) of sewer improvements, as shown on **Figure 4-3** and below in **Figure 4-6**, are identified in order to eliminate the identified nodes and SSO location to meet the required design criteria previously described.

No lift stations or associated force mains are located within the Brookhaven Sewer Basin.

Figure 4-6. Brookhaven Sewer Basin Proposed Piping Improvements



The individual pipe segments are listed in **Table 4-3**. The information presented includes the pipe ID (with corresponding upstream manhole), Branch ID (corresponding to **Figure 4-6**) that identifies the grouping, the pipe asset identification number, the existing diameter, the proposed diameter, the peak velocity, the peak flow, and the peak water depth. Peak values represent the maximum value observed during the storm event in the model analysis assuming the piping improvements have been applied.

Table 4-3. Brookhaven Sewer Basin Proposed Piping Improvements

Pipe ID	Asset ID	Branch ID	Pipe Material	L (ft)	Existing Dia (in)	Proposed Dia (in)	Peak After Improvements		
							Velocity (ft/s)	Flow (mgd)	Water Depth (ft)
112038.1	112038112039	430	UNKN	249.10	10	15	3.17	1.14	3.05
112039.1	112039112040	430	UNKN	317.50	10	15	3.03	1.14	2.28
112040.1	112040112041	430	UNKN	355.60	10	15	3.38	1.15	1.40
72002.1	072002098065	430	PVC	38.70	8	15	3.28	0.74	2.95
98007.1	098007098008	430	PVC	161.40	10	15	2.52	0.86	4.30
98008.1	098008098009	430	PVC	357.80	10	15	2.43	0.85	4.85
98009.1	098009098010	430	PVC	325.30	10	15	2.34	0.90	5.41
98010.1	098010098033	430	PVC	82.90	10	15	2.52	0.84	5.41
98033.1	098033098108	430	PVC	22.50	10	15	2.43	0.83	5.42
98034.1	098034098035	430	PVC	284.10	10	15	2.63	0.81	5.60
98035.1	098035098036	430	PVC	282.90	10	15	2.48	0.81	5.71
98036.1	098036098037	430	PVC	283.90	10	15	2.04	0.81	5.81
98037.1	098037098038	430	PVC	249.60	10	15	2.68	1.01	5.21
98038.1	098038098039	430	PVC	398.50	10	15	2.52	1.01	4.67
98039.1	098039112038	430	UNKN	285.90	10	15	2.83	1.12	3.94
98043.1	098043098007	430	UNKN	296.10	10	15	2.55	0.69	3.79
98056.1	098056098043	430	UNKN	96.40	10	15	2.19	0.70	3.43
98065.1	098065098056	430	UNKN	100.40	10	15	2.59	0.73	3.18
98108.1	098108098034	430	PVC	261.90	10	15	2.73	0.81	5.42
112041.1	112041112130	861	PVC	29.90	10	18	5.52	1.83	0.74
113004.1	113004113017	906	VCP	403.00	8	12	3.16	0.97	4.79
113008.1	113008113004	906	VCP	372.10	8	12	2.93	0.98	5.69
113017.1	113017113018	898	VCP	374.10	8	12	3.93	0.95	1.49
113018.1	113018113019	898	VCP	339.80	10	12	3.48	0.96	0.66
113019.1	113019113020	879	VCP	360.70	10	12	2.82	0.74	0.84
113020.1	113020113036	879	VCP	277.30	10	12	2.89	0.73	0.89

UNKN – information is unknown


Imhoff Sewer Basin

As illustrated on **Figure 3-4**, a total of 9 nodes are identified within the Imhoff Sewer Basin as having less than 1 foot of freeboard in the manhole. Of these nodes, 3 are predicted to have an SSO resulting in an approximate overflow quantity of 14,630 gallons under the design storm and FBO 2030 condition.

Approximately 1,750 LF (0.3 mi) of sewer improvements, as shown on **Figure 4-3** and below on **Figure 4-7**, are identified in order to eliminate the identified nodes and SSO locations to meet the required design criteria previously described.

No lift stations or associated force mains are located within the Imhoff Sewer Basin.

Figure 4-7. Imhoff Sewer Basin Proposed Piping Improvements



The individual pipe segments are listed in **Table 4-4**. The information presented includes the pipe ID (with corresponding upstream manhole), Branch ID (corresponding to **Figure 4-7**) that identifies the grouping, the pipe asset identification number, the existing diameter, the proposed diameter, the peak velocity, the peak flow, and the peak water depth. Peak values represent the maximum value observed during the storm event in the model analysis assuming the piping improvements have been applied.

Table 4-4. Imhoff Sewer Basin Proposed Piping Improvements

Pipe ID	Asset ID	Branch ID	Pipe Material	L (ft)	Existing Dia (in)	Proposed Dia (in)	Peak After Improvements		
							Velocity (ft/s)	Flow (mgd)	Water Depth (ft)
283094.1	283094283097	119	UNKN	134.30	10	12	3.16	0.83	1.61
283095.1	283095283096	119	UNKN	258.20	6	12	5.83	0.83	2.73
283096.1	283096283094	119	UNKN	88.00	6	12	6.05	0.83	2.03
283097.1	283097283098	119	UNKN	132.40	10	12	2.91	0.84	1.84
283098.1	283098283101	119	UNKN	28.90	10	12	2.88	0.85	1.87
283118.1	283118283095	119	UNKN	212.00	6	12	5.32	0.83	6.39
283128.1	283128283129	119	PVC	192.20	10	12	3.16	1.03	13.03
283129.1	283129283130	119	PVC	187.30	10	12	2.05	1.03	13.58
283130.1	283130283131	119	PVC	203.40	10	12	2.05	0.92	13.10
283131.1	283131283132	119	PVC	165.60	10	12	2.92	0.92	12.79
283132.1	283132283118	119	PVC	146.20	10	12	1.98	0.92	13.63

UNKN – information is unknown

Lift Station D Sewer Basin

As illustrated on **Figure 3-4**, a total of 10 nodes are identified in the Lift Station D Sewer Basin as having less than 1 foot of freeboard in the manhole. Of these nodes, 5 are predicted to have an SSO resulting in an approximate overflow quantity of 47,360 gallons under the design storm and FBO 2030 condition.

Approximately 14,583 LF (2.8 mi) of sewer improvements, as shown on **Figure 4-3** and below on **Figures 4-8A and 4-8B**, are identified in order to eliminate the identified nodes and SSO locations to meet the required design criteria previously described. The proposed 15-inch pipe starting just north of Nantucket Road to Ridgefield Road was previously identified in the *Northside Lift Station Preliminary Engineering Report* (HDR, May 2007).

Carrington Lift Station and Lift Station D are located in the Lift Station D Sewer Basin. Carrington Lift Station is modeled as an inactive lift station, meaning the lift station is abandoned. Refer to the Lift Station Evaluation Section for Lift Station D information. No force main improvements have been identified for Lift Station D under the design storm and FBO 2030 condition.

The individual pipe segments are listed in **Table 4-5**. The information presented includes the pipe ID (with corresponding upstream manhole), Branch ID (corresponding to **Figures 4-8A and 4-8B**) that identifies the grouping, the pipe asset identification number, the existing diameter, the proposed diameter, the peak velocity, the peak flow, and the peak water depth. Peak values represent the maximum value observed during the storm event in the model analysis assuming the piping improvements have been applied.

Figure 4-8A. Lift Station D Sewer Basin Proposed Piping Improvements




Figure 4-8B. Lift Station D Sewer Basin Proposed Piping Improvements




Table 4-5. Lift Station D Sewer Basin Proposed Piping Improvements¹

Pipe ID	Asset ID	Branch ID	Pipe Material	L (ft)	Existing Dia (in)	Proposed Dia (in)	Peak After Improvements		
							Velocity (ft/s)	Flow (mgd)	Water Depth (ft)
105012.1	105012105043	600	UNKN	44.1	10	12	3.65	1.50	9.00
105013.1	105013105057	600	UNKN	66.6	10	12	4.02	1.49	7.75
105014.1	105014105048	600	UNKN	190.8	10	12	3.52	1.46	7.06
105015.1	105015105016	600	UNKN	267	10	12	5.06	1.88	5.15
105016.1	105016105017	546	UNKN	251.6	18	21	3.51	3.83	4.98
105017.1	105017105018	546	UNKN	213.7	18	21	3.10	3.87	4.97
105018.1	105018105019	546	UNKN	233.1	18	21	3.13	3.89	4.66
105019.1	105019105020	546	UNKN	186.7	18	21	3.15	3.89	4.30
105020.1	105020105021	546	UNKN	120.8	18	21	3.37	4.14	3.92
105021.1	105021105022	546	UNKN	95.8	18	21	3.38	4.14	3.64
105022.1	105022079011	546	UNKN	393.2	18	21	3.43	4.14	2.84
105031.1	105031105015	600	UNKN	80.3	10	12	4.69	1.87	6.48
105039.1	105039105012	600	UNKN	282.6	10	12	4.14	1.51	9.01
105043.1	105043105013	600	UNKN	394.4	10	12	3.55	1.49	8.21
105057.1	105057105014	600	UNKN	343.1	10	12	4.05	1.45	7.43
119078.1	119078105011	646	UNKN	234.9	10	12	3.07	1.20	9.81
119083.1	119083119078	646	UNKN	235.5	10	12	3.58	1.19	9.93
119084.1	119084119083	646	UNKN	183.3	10	12	4.64	1.14	8.62
119085.1	119085119084	646	UNKN	222	10	12	4.15	1.13	7.56
119088.1	119088119086	646	UNKN	183.2	10	12	4.14	1.21	7.49
119089.1	119089119088	646	UNKN	329.5	10	12	3.66	1.22	7.42
119092.1	119092119089	646	UNKN	335.4	10	12	3.58	1.23	7.30
119093.1	119093119092	646	UNKN	236.5	10	12	3.53	1.28	7.17
119095.1	119095119129	646	UNKN	97.1	10	12	4.60	1.40	7.00
119123.1	119123119085	646	UNKN	256	10	12	3.22	1.13	7.60
119143.1	119143119093	646	UNKN	205.3	10	12	3.46	1.41	7.51
77005.1	077005077006	557	PVC	401.7	27	30	4.19	11.36	4.15
77006.1	7700677007	557	PVC	383.1	27	30	5.20	11.40	3.55
77007.1	077007077008	547	PVC	659.3	27	30	4.73	11.40	2.86
77008.1	077008077009	547	PVC	444.2	27	30	4.44	11.40	2.64
77009.1	077009077010	547	PVC	751.2	27	30	4.76	11.41	2.05
77010.1	077010078002	547	PVC	717.3	27	30	6.41	11.42	1.47
75016.1	7501676008	175	UNKN	158.6	12	18	6.54	2.52	5.46

Pipe ID	Asset ID	Branch ID	Pipe Material	L (ft)	Existing Dia (in)	Proposed Dia (in)	Peak After Improvements		
							Velocity (ft/s)	Flow (mgd)	Water Depth (ft)
76008.1	7600876009	175	UNKN	247	12	18	4.51	2.53	7.16
76009.1	7600976010	175	UNKN	120	12	18	4.94	2.52	6.46
76010.1	7601076011	175	UNKN	237	12	18	5.09	2.52	6.05
76011.1	7601176012	175	UNKN	235	12	18	4.85	2.54	5.77
76012.1	7601276013	175	UNKN	276	12	18	5.13	2.53	5.13
76013.1	7601376014	175	UNKN	387.3	12	18	5.03	2.53	4.79
76014.1	7601476015	175	UNKN	362	12	18	4.58	2.54	4.19
76015.1	7601576016	175	UNKN	209.8	12	18	4.68	2.54	3.32
76016.1	7601676017	175	UNKN	211.3	12	18	5.34	2.54	2.23
76017.1	7601776005	175	UNKN	343.5	12	18	5.58	2.56	2.08
79003.1	079003079002	546	UNKN	327.1	18	24	5.45	4.56	1.03
79004.1	079004079003	546	UNKN	402.7	18	24	4.25	4.56	1.34
79005.1	079005079004	546	UNKN	373.4	18	24	4.41	4.47	1.39
79006.1	079006079005	546	UNKN	400.2	18	24	4.53	4.46	1.36
79007.1	079007079006	546	UNKN	267.9	18	24	4.36	4.35	1.36
79008.1	079008079007	546	UNKN	149.2	18	24	5.33	4.33	1.00
79009.1	079009079008	546	UNKN	174.8	18	24	3.85	4.33	1.43
79010.1	079010079009	546	UNKN	281.5	18	24	3.54	4.22	1.99
79011.1	079011079010	546	UNKN	380.2	18	24	4.70	4.15	2.26

UNKN – information is unknown

¹At the time of flow monitoring described, Lift Station D was still under construction so all flow was conveyed to the Brookhaven Sewer Basin. As described in the previous chapter, the model development included the Lift Station D improvements, where flow is now conveyed to the Lift Station D Sewer Basin and ultimately to Lift Station D.

This page intentionally left blank.

Normandy Sewer Basin

As illustrated in **Figure 3-4**, a total of 13 nodes are identified within the Normandy Sewer Basin as having less than 1 foot of freeboard in the manhole. Of these nodes, 6 are predicted to have an SSO resulting in an approximate overflow quantity of 118,790 gallons under the design storm and FBO 2030 condition.

Approximately 11,350 LF (2.2 mi) of sewer improvements, shown on **Figure 4-3** and below on **Figures 4-9A and 4-9B**; are identified in order to eliminate the identified nodes and SSO locations to meet the required design criteria previously described. These sewer improvements are associated with a trunk line conveying flow out of the Normandy Sewer Basin.

No lift stations or associated force mains are located within the Normandy Sewer Basin.

The individual pipe segments are listed in **Table 4-6**. The information presented includes the pipe ID (with corresponding upstream manhole), Branch ID (corresponding to **Figures 4-9A and 4-9B**) that identifies the grouping, the pipe asset identification number, the existing diameter, the proposed diameter, the peak velocity, the peak flow, and the peak water depth. Peak values represent the maximum value observed during the storm event in the model analysis assuming the piping improvements have been applied.

Figure 4-9A. Normandy Sewer Basin Proposed Piping Improvements






Figure 4-9B. Normandy Sewer Basin Proposed Piping Improvements




Table 4-6. Normandy Sewer Basin Proposed Piping Improvements

Pipe ID	Asset ID	Branch ID	Pipe Material	L (ft)	Existing Dia (in)	Proposed Dia (in)	Peak After Improvements		
							Velocity (ft/s)	Flow (mgd)	Water Depth (ft)
208066.1	208066208067	92	UNKN	301.5	8	12	4.22	0.82	4.63
208022.1	208022208023	184	VCP	216.5	6	8	-1.51	-0.24	4.39
208023.1	208023208024	184	VCP	165.7	6	8	-1.37	-0.23	5.94
238087.1	238087254080	576	PVC	169.3	21	24	4.81	5.97	3.68
254010.1	254010254076	576	PVC	221.6	21	24	3.76	6.01	3.15
254017.1	254017254027	576	PVC	277.1	21	24	5.25	5.97	2.60
254027.1	254027254020	576	PVC	74.5	21	24	4.40	5.95	2.71
254046.1	254046254047	576	PVC	152.1	21	24	3.67	6.00	3.93
254047.1	254047254077	576	PVC	151.4	21	24	3.69	6.01	3.72
254076.1	254076254017	576	PVC	110.9	21	24	4.03	6.01	2.91
254077.1	254077254010	576	PVC	242.1	21	24	3.88	6.01	3.29
254080.1	254080254046	576	PVC	281	21	24	3.66	6.00	4.12
238065.1	238065238084	607	PVC	189.2	21	24	4.76	5.96	3.82
238084.1	238084238085	607	PVC	136	21	24	3.64	5.96	3.88
238085.1	238085238086	607	PVC	122	21	24	3.65	5.96	3.66
238086.1	238086238087	607	PVC	369.1	21	24	5.49	5.96	2.98
239109.1	239109238065	607	PVC	142.5	21	24	5.93	5.75	2.71
239012.1	239012239106	618	PVC	231.8	21	24	3.79	5.81	2.54
239015.1	239015239016	618	PVC	106.9	21	24	3.84	5.64	2.07
239016.1	239016239017	618	PVC	246.5	21	24	3.93	5.63	2.01
239017.1	239017239107	618	PVC	148.6	21	24	4.20	5.62	1.94
239106.1	239106239125	618	PVC	163.9	21	24	3.77	5.81	2.43
239107.1	239107239108	618	PVC	183	21	24	5.40	5.61	1.88
239108.1	239108239109	618	PVC	82.7	21	24	5.74	5.59	2.10
239125.1	239125239131	618	PVC	228.6	21	24	3.63	5.64	2.38
239131.1	239131239015	618	PVC	74.7	21	24	3.73	5.64	2.21
208011.1	208011208114	637	PVC	296	18	24	4.51	5.80	7.64
208114.1	208114208115	637	PVC	88.3	18	24	4.51	5.79	7.56
208115.1	208115208116	637	PVC	139.4	18	24	4.56	5.78	6.75
208116.1	208116208117	637	PVC	149.8	18	24	4.62	5.78	5.85
208117.1	208117208118	637	PVC	128.7	18	24	4.68	5.78	5.07
208118.1	208118208119	637	PVC	122.6	18	24	4.73	5.80	4.68
208119.1	208119208120	637	PVC	192.4	18	24	4.80	5.79	3.63

Pipe ID	Asset ID	Branch ID	Pipe Material	L (ft)	Existing Dia (in)	Proposed Dia (in)	Peak After Improvements		
							Velocity (ft/s)	Flow (mgd)	Water Depth (ft)
208120.1	208120208121	637	PVC	171.8	18	24	5.18	5.79	2.79
208121.1	208121208122	637	PVC	167.7	21	24	4.67	5.77	2.72
208122.1	208122239130	637	PVC	363.7	27	24	2.60	5.77	3.33
239120.1	239120239012	637	PVC	167	21	24	3.80	5.76	2.67
239130.1	239130239120	637	PVC	380.2	21	24	3.65	5.76	2.84
208005.1	208005208006	668	UNKN	228.1	8	12	2.77	0.65	6.93
208006.1	208006208007	668	UNKN	345.2	8	12	2.64	0.63	7.18
208007.1	208007208008	668	UNKN	396.8	8	12	2.76	0.61	7.23
208008.1	208008208009	668	UNKN	401.1	8	12	3.03	0.61	7.43
208009.1	208009208010	668	UNKN	185.3	8	12	2.28	0.60	8.08
208010.1	208010208011	668	UNKN	99.7	8	15	5.91	1.33	7.71
208067.1	208067208010	677	UNKN	185.9	8	12	3.41	0.83	8.07
208050.1	208050208066	715	UNKN	50.8	8	12	2.83	0.68	4.61
208046.1	208046208050	718	UNKN	240.7	8	12	2.73	0.66	4.50
208028.1	208028208039	720	UNKN	248.7	8	12	3.23	0.86	4.40
208039.1	208039208040	720	UNKN	131.5	8	12	3.31	0.86	3.78
208040.1	208040208046	720	UNKN	148.2	8	12	2.59	0.65	4.03
192019.1	192019192020	736	VCP	198.6	8	12	2.40	0.60	4.21
192020.1	192020208005	736	VCP	246.3	8	12	3.26	0.47	4.98
208019.1	208019208027	741	UNKN	430.3	8	12	3.40	0.80	5.75
208027.1	208027208028	741	UNKN	79.2	8	12	2.94	0.81	5.64
208136.1	208136208026	761	VCP	115.5	6	8	3.16	0.45	7.57
208024.1	208024208025	767	VCP	218.1	6	8	3.63	0.40	5.74
208025.1	208025208136	767	VCP	245.2	6	8	2.74	0.40	8.67

UNKN – information is unknown

This page intentionally left blank.

Tecumseh Sewer Basin

As illustrated on **Figure 3-4**, one node was identified in the Tecumseh Sewer Basin as having less than 1 foot of freeboard in the manhole. No SSOs occurred under the FBO 2030 design storm scenario.

Approximately 723 LF (0.14 miles) of sewer improvements, shown on **Figure 4-3** and below on **Figure 4-10**, are identified in order to eliminate the identified deficiency at the node to meet the required design criteria previously described.

Figure 4-10. Tecumseh Sewer Basin Proposed Piping Improvements



The individual pipe segments are listed in **Table 4-7**. The information presented includes the pipe ID (with corresponding upstream manhole), Branch ID (corresponding to **Figure 4-10**) that identifies the grouping, the pipe asset identification number, the existing diameter, the proposed diameter, the peak velocity, the peak flow, and the peak water depth. Peak values represent the maximum value observed during the design storm event in the model analysis assuming the piping improvements have been applied.

Table 4-7. Tecumseh Sewer Basin Proposed Piping Improvements

Pipe ID	Asset ID	Branch ID	Pipe Material	L (ft)	Existing Dia (in)	Proposed Dia (in)	Peak After Improvements		
							Velocity (ft/s)	Flow (mgd)	Water Depth (ft)
101028.1	10102875013	175	UNKN	100.6	12	18	4.59	2.66	8.19
75013.1	75013075017	175	UNKN	205	12	18	4.79	2.64	6.31
75017.1	75017075015	175	UNKN	140	12	18	4.91	2.63	5.30
75015.1	7501575016	175	UNKN	278	12	18	5.66	2.61	4.76


UNKN – information is unknown

Westside Sewer Basin

As illustrated on **Figure 3-4**, a total of 2 nodes are identified in the Westside Sewer Basin as having less than 1 foot of freeboard in the manhole. Both of these nodes are predicted to have an SSO resulting in an approximate overflow quantity of 21,218 gallons under the design storm and FBO 2030 condition.

Approximately 1,537 LF (0.3 mi) of sewer improvements shown on **Figure 4-3** and below on **Figure 4-11** are identified in order to eliminate the identified nodes and SSO locations to meet the required design criteria previously described.

Figure 4-11. Westside Sewer Basin Proposed Piping Improvements



The individual pipe segments are listed in **Table 4-8**. The information presented includes the pipe ID (with corresponding upstream manhole), Branch ID (corresponding to **Figure 4-11**) that identifies the grouping, the pipe asset identification number, the existing diameter, the proposed diameter, the peak velocity, the peak flow, and the peak water depth. Peak values represent the maximum value observed during the design storm event in the model analysis assuming the piping improvements have been applied.

Table 4-8. Westside Sewer Basin Proposed Piping Improvements

Pipe ID	Asset ID	Branch ID	Pipe Material	L (ft)	Existing Dia (in)	Proposed Dia (in)	Peak After Improvements		
							Velocity (ft/s)	Flow (mgd)	Water Depth (ft)
328013.1	328013328056	4	DIP	54.6	48	54	7.5	33.6	5.1
328051.1	328051328052	3	PVC	302.3	42	48	4.3	21.0	5.4
328052.1	328052328653	3	PVC	342.8	42	48	6.7	24.6	5.3
328055.1	328055328056	1	DIP	142.3	24	36	10.7	25.0	11.1
329024.1	329024328013	4	FRP	695.4	48	54	5.9	32.6	5.5

UNKN – information is unknown

York Sewer Basin

As illustrated on **Figure 3-4**, a total of 5 nodes are identified in the York Sewer Basin as having less than 1 foot of freeboard in the manhole. Three of these nodes are predicted to have an SSO resulting in an approximate overflow quantity of 141,560 gallons under the design storm and FBO 2030 condition.

Approximately 5,810 LF (1.1 mi) of sewer improvements shown on **Figure 4-3** and below in **Figure 4-12** are identified in order to eliminate the identified nodes and SSO locations to meet the required design criteria previously described.

The individual pipe segments are listed in **Table 4-9**. The information presented includes the map ID (corresponding to **Figure 4-12**), the pipe asset identification number, the existing diameter, the proposed diameter, the peak velocity, the peak flow, and the peak water depth. Peak values represent the maximum value observed during the storm event in the model analysis assuming the piping improvements have been applied. In general, 12- inch diameter pipe needs to be upsized to 18-inch pipe to convey the FBO 2030 design storm flow. Some 8-inch pipe needs to be upsized to 18-inches to convey the flow.

The York Lift Station located in the York Sewer Basin was modeled as inactive, meaning this lift station is no longer in service.

Figure 4-12. York Sewer Basin Proposed Piping Improvements






Table 4-9. York Sewer Basin Proposed Piping Improvements

Pipe ID	Asset ID	Branch ID	Pipe Material	L (ft)	Existing Dia (in)	Proposed Dia (in)	Peak After Improvements		
							Velocity (ft/s)	Flow (mgd)	Water Depth (ft)
44010.1	044010044011	97	PVC	255	18	18	2.4	0.9	11.8
44011.1	044011070001	97	PVC	259	12	18	3.3	1.0	12.9
70001.1	070001070034	97	VCP	85	8	18	2.9	1.0	12.9
70031.1	070031070032	97	VCP	461	8	18	3.5	1.0	11.2
70032.1	070032070033	97	VCP	386	8	18	4.9	1.2	4.4
70033.1	070033070006	97	VCP	263	8	18	6.7	1.4	0.6
70034.1	070034070031	97	VCP	294	8	18	3.1	1.0	9.8
42010.1	042010042011	299	PVC	128	12	18	-1.6	-1.0	8.5
70035.1	070035070036	647	PVC	217	12	18	2.8	1.5	1.3
70051.1	070051070052	647	PVC	85	12	18	3.8	1.5	0.7
70052.1	070052070053	647	PVC	229	12	18	4.2	1.5	0.6
70053.1	070053070054	647	PVC	112	12	18	4.9	1.5	0.6
70054.1	070054070035	647	PVC	218	12	18	5.1	1.5	0.6
42008.1	042008044001	833	PVC	278	12	18	3.2	1.1	8.9
42011.1	042011042008	833	PVC	17	12	18	2.1	1.1	8.7
44001.1	044001044002	833	PVC	399	12	18	2.6	1.0	9.9
44002.1	044002044003	833	PVC	408	12	18	3.3	0.8	10.6
44003.1	044003044004	833	PVC	400	12	18	1.3	0.7	11.6
44004.1	044004044005	833	PVC	418	12	18	2.9	1.3	11.0
44005.1	044005044006	833	PVC	395	12	18	2.6	1.3	10.8
44006.1	044006044007	833	PVC	110	12	18	2.5	1.3	10.8
44007.1	044007044008	833	PVC	127	12	18	2.4	1.3	10.7
44008.1	044008044009	833	PVC	118	12	18	3.5	1.0	10.7
44009.1	044009044010	833	PVC	149	18	18	2.6	1.0	11.1

UNKN – information is unknown

4.3.2 Lift Station and Force Main Evaluation

A summary of the modeled lift station conditions is shown in **Table 4-10**.

Table 4-10. Existing Lift Station Model Conditions

Lift Station Name	Lift Station ID	Pump 1 Operating Point ² (mgd @ TDH, ft)	On Level 1 (ft) ¹	On Level 2 (ft) ³	On Level 3 (ft) ³
Alameda Park	215701-Wetwell	0.12 @ 39.3	1170.97	1171.09	-
Ashton Grove	111700-Wetwell	1.01 @ 72	1111.60	1111.90	-
Eagle Cliff	357700-Wetwell	0.26 @ 62	1076.60	1078.00	-
East Ridge	289700-Wetwell	0.43 @ 43	1142.50	1144.50	1146.50
Hall Park North	154001-Wetwell	0.87 @ 125	1123.50	1124.50	-
Hall Park South	168004-Wetwell	0.65 @ 136.8	1139.00	1140.50	-
Lift Station D	79700-Wetwell	6.0 @ 281	See Note 4	-	-
Park Hill	107038-Wetwell	0.21 @ 120	1153.50	1154.50	-
Post Oak	360701-Wetwell	1.01 @ 90	1121.00	1122.00	-
Royal Oaks	216700-Wetwell	0.87 @ 84.5	1139.75	1142.90	-
Siena Springs	264700-Wetwell	0.21 @ 35	1179.50	1180.50	-
Summit Lakes	248701-Wetwell	0.25 @ 101	1172.70	1173.70	-
Summit Valley	301700-Wetwell	1.12 @ 72	1112.02	1112.50	-
Sutton Place	165700-Wetwell	0.30 @ 76	1167.00	1167.00	-
Vo-Tech	55700-Wetwell	0.21 @ 50	1138.14	1138.64	-
Westside	328700-Wetwell	8.96 @ 41.3	1080.50	1081.20	1081.20

¹Below Level 1, the pump rate is zero.

²Between Level 1 and Level 2, the pump rate is Flow Rate 1. Operating point is the flow rate which pump operates at in the model and may differ from the pump's actual design point.

³Above Level 2 and Level 3, Lag 1 (and Lag 2, if available) are operating

⁴Lift Station D operates at a maximum of 6 mgd and maintains a set wet well level.

⁵Inactive lift stations are considered abandoned and were not included in the modeled condition.

The lift station capacity was evaluated for the design storm and FBO 2030 loading condition against the existing station firm and total pumping capacity. Firm pumping capacity is defined as having all pumps but one available for operation.

Table 4-11 summarizes the lift station capacity evaluation in terms of peak 2-hour flow and average design flow. Lift stations are typically designed for the peak 2-hour flow condition; however ODEQ requires only the effective volume of the wet well to be based on design average flow and a filling time not to exceed 30 minutes unless the facility is designed to provide flow equalization.



Table 4-11. Existing Lift Station and Force Main Capacity Evaluation

Lift Station Name	Existing Capacity		Peak 2-Hour Flow ²			Average Design Flow ³			Force Main		
	Total (mgd)	Firm ¹ (mgd)	Predicted (mgd)	Remaining Firm Capacity (mgd)	Remaining Total Capacity (mgd)	Water Depth from Wetwell Rim (ft)	Predicted (mgd)	Remaining Firm Capacity (mgd)	Existing Diameter (in)	Velocity at P2H Flow (ft/sec)	Velocity at Avg. Design Flow (ft/sec)
Alameda Park	0.24	0.12	0.11	0.01	0.13	-19.5	0.03	0.09	4	2.7	2.3
Ashton Grove	2.02	1.01	0.56	0.45	1.46	-23.2	0.19	0.82	12	3.5	2.7
Eagle Cliff	0.52	0.26	0.07	0.19	0.45	-11.5	0.04	0.22	6	3.2	2.3
East Ridge	2.34	0.78	0.61	0.17	1.73	-13.0	0.14	0.64	8	9.9	5.4
Hall Park North	1.74	0.87	1.47	-0.60	0.27	-7.7	0.40	0.47	8	6.3	4.6
Hall Park South	1.30	0.65	2.33	-1.68	-1.03	-11.3	0.61	0.04	12	4.7	3.2
Lift Station D	6.00	6.00	21.14	-15.14 ⁴	-15.14 ⁴	-13.5	4.88	1.12	16	6.6	5.4
Park Hill	0.42	0.21	0.08	0.13	0.34	-10.4	0.04	0.17	4	4.0	3.1
Post Oak	2.02	1.01	0.58	0.43	1.44	-10.6	0.18	0.83	12	3.3	2.2
Royal Oaks	1.74	0.87	1.52	-0.65	0.22	-8.0	0.39	0.48	12	3.4	2.2
Siena Springs	0.42	0.21	0.18	0.03	0.24	-8.9	0.04	0.17	8	4.9	2.7
Summit Lakes	0.50	0.25	0.15	0.10	0.35	-10.8	0.04	0.21	4	4.3	3.7
Summit Valley	2.24	1.12	0.44	0.68	1.80	-14.7	0.22	0.90	12	3.0	2.2
Sutton Place	0.59	0.30	0.62	-0.33	-0.03	-7.0	0.03	0.26	6	5.2	4.6
Vo-Tech	0.42	0.21	0.72	-0.51	-0.30	-16.4	0.09	0.12	10	3.0	1.6
Westside	26.88	17.92	20.14	-2.22	6.74	-15.8	6.28	11.64	24	11.9	4.4

¹Firm Capacity based on Operating Point listed in Table 4-10

²P2HF is the predicted peak two-hour flow under the design storm and FBO 2030 condition

³Average Design Flow is the predicted average flow under the design storm and FBO 2030 condition

⁴While the firm pumping capacity of Lift Station D is only 6 mgd, sufficient equalization storage is available to handle the excess peak two-hour flow and is integral to the design of the station and equalization storage. Thus, the facility as a whole currently has the capacity to handle P2H FBO 2030 flows.

Lift Station Capacity Evaluation

FBO 2030 Average Design Flow: All of the lift stations in the City's system currently have the firm capacity to handle FBO 2030 average design flows.

Firm Capacity at FBO 2030 Peak 2-hour Flow: Six lift stations (Hall Park North, Hall Park South, Royal Oaks, Sutton Place, Vo-Tech, and Westside) are predicted to receive FBO 2030 P2H flows in excess of their firm pumping capacities (see bolded values in **Table 4-11**). However, as shown in the table, none of the lift station wetwells overflow under P2H flows. The upstream gravity piping water levels rise slightly to handle this additional flow without creating overflows in the upstream manholes. As a result, the firm capacity for all of the lift stations is adequate for FBO 2030 P2H flows.

Total Capacity at FBO 2030 Peak 2-hour Flow: Three lift stations (Hall Park South, Sutton Place, and Vo-Tech) are predicted to receive FBO 2030 P2H flows in excess of their total pumping capacities (see bolded values in **Table 4-11**). However, as discussed above, the upstream gravity piping has the capacity to store the additional flow and the existing lift station capacities are adequate.

Force Main Evaluation

FBO 2030 Average Design Flow: For FBO 2030 average design flows, the velocities in all of the force mains are below 6 feet per second, which is less than the stated evaluation criterion maximum of 7 feet per second.

FBO 2030 Peak 2-hour Flow: For FBO 2030 P2H flows, the force mains at two lift stations (East Ridge and Westside) experience velocities higher than the evaluation criteria (see bolded values in **Table 4-11**). In both cases, however, the velocities are not high enough to create excessive headloss in the system, and the pumps are able to convey the necessary flow. It is not recommended that these two force mains be upsized. However, the City may want to consider paralleling the Westside force main in the future to provide additional reliability since it is a critical facility at the existing Norman WRF.

Recommendations

Based on this evaluation, there are no lift station improvements necessary to meet the FBO 2030 flows. Also, all of the existing force mains are adequately sized to convey these flows, so no force main improvements are needed.

The analysis identified two lift stations that could be eliminated to simplify system operations:

- The Siena Springs Lift Station could be eliminated by consolidating flow with the East Ridge Lift Station as proposed by the developer of the Stone Lake Subdivision. The East Ridge Lift Station has the remaining capacity to handle this additional flow.
- The Vo-Tech Lift Station could be eliminated by constructing a gravity sewer to the Little River Interceptor.

4.3.3 Estimated Construction Costs

A summary of the estimated capital costs for the recommended improvements to the existing collection system shown on **Figure 4-3** is listed in **Table 4-12**. For the purpose of this planning level cost estimate, it is assumed that the gravity sewers are being replaced with the proposed diameters rather than installing a parallel sewer. Evaluating whether to construct parallel sewers versus replacement is typically performed during the design phase of an individual project to determine the most cost-effective approach.

Table 4-12. Estimated Gravity System Improvement Costs for the One-Plant Scenario

Sewer Basin	Length of Pipe (ft)	Length of Pipe (mi)	Estimated Construction Cost	Sewer Shed
LS D	14,583	2.8	\$2,898,912	North
Tecumseh	724	0.2	\$132,079	North
York	5,810	1.1	\$1,060,426	North
Subtotal North	21,117	4.0	\$4,091,417	
Bishop	24,223	4.6	\$5,929,482	South
Brookhaven	6,607	1.3	\$1,031,627	South
Imhoff	1,748	0.3	\$247,990	South
Normandy	11,352	2.2	\$2,106,138	South
Westside	1,537	0.3	\$608,788	South
Subtotal South	45,469	8.6	\$9,924,025	
Total	66,586	12.6	\$14,015,442	

4.3.4 Norman WRF Design Flow

Predicted wastewater flows occurring under a 5-year, 4-hour design storm event using the FBO 2030 loading condition, with the improvements in place, were determined as shown in **Figure 4-1**. The wastewater flows were summed to determine the expected flow to the Norman WRF. The summary of these flows is included in **Table 4-13**.

Table 4-13. Predicted Norman WRF Wastewater Flows for One-Plant Scenario

Parameter	Description	Historical Data	Predicted for One-Plant Scenario, FBO 2030
Flow (mgd)	Average Dry Weather ¹	10.5	18.6
	Annual Average ²	11.1	18.3 ⁶
	Annual Average Plus Planning Capacity ³	11.7	19.2
	Maximum Month ⁴	12.6	-
	Maximum Month + Planning Capacity	13.2	-
	Maximum Day ⁵	21.3	33.5
	Peak 2-hour	-	70.8

¹Review of wastewater treatment plant influent record data from May 2010 to September 2010, dry weather only, to coincide with the flow monitoring period.

²Review of wastewater treatment plant influent record data from October 2009 to September 2010. This is an annual average of all monthly data and includes dry and wet weather flow events.

³Planning capacity = 5%.

⁴Review of monthly flow volume totals from October 2009 to September 2010. The maximum month flow was identified and divided by 30 days.


⁵Review of daily wastewater plant influent record data from October 2009 to September 2010.

⁶Predicted annual average = predicted average dry weather/0.98



The predicted wet weather flow curve is shown on **Figure 4-13**.

Figure 4-13. Predicted Norman WRF Flow Curve for One-Plant Scenario for Peak 2-Hour FBO 2030



4.4 Two-Plant Scenario

This section describes the evaluation with the system flow at a FBO 2030 loading condition under a 5-year, 4-hour storm event being conveyed as follows:

- All North Basin flow conveyed from Lift Station D to a proposed North WRF.
- All South Basin flow conveyed to the existing Norman WRF.

4.4.1 Pipeline System Evaluation

With the 6 mgd maximum flow from Lift Station D contributing flow to the South Sewer Shed removed, the model was run to predict capacity and SSO issues (as defined in Chapter 3) during a 5-year, 4-hour design storm event when the FBO 2030 loading is applied to the existing sewer system.


Fifty (50) total locations were identified as not meeting the design capacity criteria. These locations are shown on **Figure 4-14** and listed in **Table 4-14**. Of the 50 locations, 23 manholes are identified as SSO locations resulting in a predicted overflow volume of approximately 0.45 million gallons (MG). Twenty-seven (27) locations are identified as having less than one foot of freeboard available.

The model output data for the design storm and FBO 2030 loading condition for all conduits (pipe segments) after all the improvements described herein are implemented are included in **Appendix 4E**.


Very little difference exists between the One-Plant Scenario data (**Table 3-3**) and the Two-Plant Scenario data shown in **Table 4-14**. In the Two-Plant Scenario, the 6 mgd from Lift Station D is redirected to the proposed North WRF and not discharged into the south sewer shed via the Bishop Sewer Basin (as currently performed).




This page intentionally left blank.




INSET 1



INSET 2




INSET 3



CITY OF NORMAN FLOW MONITORING AND MODELING

CAPACITY ISSUE LOCATIONS
TWO PLANT SCENARIO
FBO 2030 5-YEAR 4-HOUR STORM
FLOW CONDITION



MODELED SYSTEM LEGEND

- ▲ Inactive Lift Station
- ▲ Active Lift Station
- FB
- SSO
- Conduit
- WTP Outfall
- Force Main
- Flow Division Line
- City Boundary
- Street Centerlines

SOURCE: CITY OF NORMAN INFRASTRUCTURE AS OF APRIL 2012

INSET MAPS NOT TO SCALE



HDR HDR ENGINEERING, INC.
17111 PRESTON ROAD, SUITE 300
DALLAS, TEXAS 75248-1232
(972) 960-4400

FIGURE 4-14

This page intentionally left blank.

Table 4-14. Design Storm Capacity Issues at FBO 2030 – Two-Plant Scenario


Map ID	Sewer Basin	Manhole ID	Rim Elevation	Maximum Water Level Elevation	Freeboard to Manhole Rim (ft)	SSO (Y or N)	Estimated Overflow (gallons)
37	Bishop	243056	1141.00	1141.00	0.00	Y	6,600
38	Bishop	263037	1208.88	1208.88	0.00	Y	45,400
47	Bishop	321075	1116.67	1116.67	-0.75	N	0
Subtotal Bishop							52,000
6	Brookhaven	72002	1188.24	1188.24	0.00	Y	42,100
7	Brookhaven	72008	1192.55	1192.55	-0.91	N	0
8	Brookhaven	72024	1192.78	1192.78	-0.22	N	0
10	Brookhaven	98065	1188.19	1188.19	0.00	Y	100
16	Brookhaven	113008	1180.03	1180.03	0.00	Y	9,600
Subtotal Brookhaven							51,800
23	Imhoff	162002	1191.41	1191.41	-0.59	N	0
39	Imhoff	283037	1152.00	1152.00	0.00	N	0
40	Imhoff	283118	1144.00	1144.00	0.00	Y	12,200
41	Imhoff	283125	1151.24	1151.24	0.00	Y	1000
42	Imhoff	283128	1147.80	1147.80	-0.28	N	0
43	Imhoff	283129	1146.91	1146.91	-0.52	N	0
44	Imhoff	283130	1146.00	1146.00	0.00	Y	1,500
45	Imhoff	283131	1145.28	1145.28	-0.45	N	0
46	Imhoff	283132	1144.63	1144.63	-0.76	N	0
Subtotal Imhoff							14,700
9	Lift Station D	76008	1143.34	1143.34	-0.66	N	0
12	Lift Station D	105012	1134.00	1134.00	0.00	Y	8,200
13	Lift Station D	105014	1127.13	1127.13	-0.87	N	0
14	Lift Station D	105039	1136.50	1136.50	0.00	Y	7,700
15	Lift Station D	105043	1133.62	1133.62	-0.88	N	0
17	Lift Station D	118008	1158.86	1158.86	0.00	Y	1,600
18	Lift Station D	118015	1162.12	1162.12	-0.63	N	0
19	Lift Station D	119085	1142.10	1142.10	-0.36	N	0
20	Lift Station D	119092	1148.42	1148.42	0.00	Y	20,500
21	Lift Station D	119093	1150.19	1150.19	0.00	Y	9,400
Subtotal Lift Station D							47,400
24	Normandy	192020	1147.10	1147.10	0.00	Y	23,800
25	Normandy	192029	1151.86	1151.86	-0.48	N	0




Map ID	Sewer Basin	Manhole ID	Rim Elevation	Maximum Water Level Elevation	Freeboard to Manhole Rim (ft)	SSO (Y or N)	Estimated Overflow (gallons)
26	Normandy	192030	1149.77	1149.77	-0.39	N	0
27	Normandy	192031	1148.29	1148.29	0.00	Y	3,000
28	Normandy	192033	1151.73	1151.73	0.00	Y	100
29	Normandy	207003	1162.36	1162.36	-0.85	N	0
30	Normandy	207061	1158.90	1158.90	-0.15	N	0
31	Normandy	208022	1157.13	1157.13	0.00	Y	22,500
32	Normandy	208044	1143.00	1143.00	0.00	Y	60,300
33	Normandy	208045	1143.44	1143.44	-0.47	N	0
34	Normandy	208072	1141.10	1141.10	-0.90	N	0
35	Normandy	208079	1141.06	1141.06	0.00	Y	9,200
36	Normandy	239042	1135.25	1135.25	-0.85	N	0
Subtotal Normandy							118,900
22	Park Hill	121012	1210.71	1210.71	-0.94	N	0
Subtotal Park Hill							0
11	Tecumseh	102008	1153.26	1153.26	-0.47	N	0
Subtotal Tecumseh							0
48	Westside	328055	1124.60	1124.60	0.00	Y	21,200
Subtotal Westside							21,200
1	York	42006	1168.12	1168.12	0.00	Y	78,600
2	York	44008	1166.11	1166.11	0.00	Y	18,300
3	York	44009	1166.05	1166.05	-0.94	N	0
4	York	44010	1166.03	1166.03	-0.67	N	0
5	York	70031	1160.00	1160.00	0.00	Y	44,700
Subtotal York							141,600
Total North Sewer Shed							189,000
Total South Sewer Shed							258,600
Total All Basins							447,600

The locations of the proposed pipeline improvements to eliminate these 50 capacity excursions are shown collectively on **Figure 4-15**. Like the One-Plant Scenario, it is assumed all gravity pipeline improvements are replacement lines for this planning level evaluation.

Of the approximately 66,586 LF of identified gravity sewer improvements under the One-Plant Scenario, about 4,500 LF would not need improvement under the Two-Plant Scenario due to the decrease in flow loading. A summary of the difference in gravity piping lengths per sewer basin is given in **Table 4-15**.



CITY OF NORMAN
FLOW MONITORING AND MODELING
 RECOMMENDED PIPING IMPROVEMENTS
 TWO PLANT SCENARIO
 FBO 2030, 5-YEAR 4-HOUR STORM
 FLOW CONDITION



HDR HDR ENGINEERING, INC.
 17111 PRESTON RD, SUITE 300
 DALLAS, TX 75248-1232
 972-960-4400

FIGURE 4-15


PATH: C:\USERS\TWHITFE\DOCUMENTS\WORKING DOCUMENTS\PROJECTS_ACTIVE\NORMAN_NORMAN_GIS\MAP_DOCS\MXD\2017_FIGURE_RECREATION\FIGURE4-15.MXD - USER: TWHITFE - DATE: 1/11/2017

Table 4-15. Comparison of Gravity Piping Improvements Between One-Plant and Two-Plant Scenarios

Sewer Basin	One-Plant Scenario Length of Pipe (ft)	Two-Plant Scenario Length of Pipe (ft)	Length Difference (ft)
Bishop	24,223	19,700	4,524
Brookhaven	6,607	6,607	0
Imhoff	1,748	1,748	0
LS D	14,584	14,584	0
Normandy	11,352	11,352	0
Tecumseh	724	724	0
Westside	1,538	1,538	0
York	5,810	5,810	0
Total	66,586	62,062	4,524

As listed in **Table 4-15**, piping improvements needed for the One-Plant Scenario but not the Two-Plant Scenario are all located within the Bishop Sewer Basin. **Figure 4-16** highlights the location of the pipe segments that differ between the two scenarios. The two figures below illustrate improvements recommended for the One-Plant Scenario only (Segments 80, 609, 660 and 689).

Figure 4-16. Gravity Piping Improvements in Bishop Creek Basin Not Needed for Two-Plant Scenario



Note: All gravity improvements identified previously for the One-Plant Scenario are also needed for the Two-Plant Scenario except for the improvements shown in this figure.

4.4.2 Lift Station and Force Main Evaluation

As with the majority of the piping improvements, redirecting the North Sewer Shed flow to a proposed North WRF has no affect on the lift station and force main evaluation conducted previously for the One-Plant Scenario. No force main or lift station improvements are needed for either scenario.

4.4.3 Estimated Construction Costs

A summary of the estimated capital costs for the recommended improvements to the existing gravity collection system are included below in **Table 4-16**.

Table 4-16. Estimated Gravity System Improvement Costs for the Two-Plant Scenario¹

Basin	Length of Pipe (ft)	Length of Pipe (mi)	Estimated Cost	Sewer Shed
LS D	14,583	2.8	\$2,844,517	North
Tecumseh	724	0.2	\$132,079	North
York	5,810	1.1	\$1,060,426	North
Subtotal North	21,117	4.0	\$4,037,022	
Bishop	19,700	3.7	\$4,639,965	South
Brookhaven	6,607	1.3	\$1,031,627	South
Imhoff	1,748	0.3	\$247,990	South
Normandy	11,352	2.2	\$2,106,138	South
Westside	1,537	0.3	\$608,788	South
Subtotal South	40,945	7.8	\$8,634,508	
Total	62,062	11.8	\$12,671,530	

¹The estimated costs are the same as the One-Plant Scenario listed in Table 4-12, except for the Bishop Sewer Basin.

Table 4-17 compares the estimated improvements costs for the One-Plant Scenario versus the Two-Plant Scenario.

Table 4-17. Difference in Improvement Costs Between One-Plant and Two-Plant Scenarios

Improvement Type	One-Plant Scenario Estimated Cost	Two-Plant Scenario Estimated Cost	Difference
Gravity Pipe Improvements	\$14,015,442	\$12,671,530	\$1,343,912
Total	\$14,015,442	\$12,671,530	\$1,343,912

4.4.4 Norman WRF and North WRF Design Flows

Predicted wastewater flows occurring under a 5-year, 4-hour design storm event using the FBO 2030 loading condition were determined for the South Sewer Shed flowing to the existing Norman WRF and the North Sewer Shed flowing to a proposed North WRF. The summary of these flows is included in **Table 4-18**.


Table 4-18. Predicted WRF Wastewater for Two-Plant Scenario

Parameter	Description	Predicted for Two-Plant Scenario, FBO 2030	
		Norman WRF	North WRF
Flow (mgd)	Average Dry Weather	17.4	3.2
	Annual Average ¹	17.1	3.1
	Annual Average Plus Planning Capacity ²	17.9	3.3
	Maximum Day ³	28.2	6.4
	Peak 2-hour Flow	64.4	17.7

¹Annual average = predicted average dry weather flow x 0.98
²Planning Capacity = 5%
³Maximum predicted wet weather flow over a 24-hour period

The predicted wet weather flow curve is shown on **Figure 4-17**.

Figure 4-17. Predicted Norman WRF and North WRF Flow Curves for Two-Plant Scenario for Peak 2-Hour FBO 2030



5 Evaluation Results Summary

5.1 Effectiveness of Recent Improvements

After incorporating updated flow monitoring data and calibrating the updated model, it was determined that the collection system improvements that Norman has implemented since the previous master plan was completed in 2001 have been very effective in reducing inflow and infiltration (I/I). The bulk of improvements occurred in the Bishop Creek basin, and I/I appears to have been reduced by up to 72%. The estimated percent reduction in I/I for all basins analyzed is shown in **Table 3-4**.

5.2 Recommended Future Collection System Improvements for Full Build-Out 2030 Flows

A total of 16.0 miles of sewer improvements (gravity and force main) have been identified under the One-Plant Scenario, whereas a total of 15.1 miles of sewer improvements have been identified under the Two-Plant Scenario. In essence, the collection system and lift station improvements are largely independent of whether or not a second WRF is implemented. This is mainly due to the significant improvements the City has already made in the Bishop Creek basin to carry northside flows to the existing WRF.

The improvements recommended to maintain the design criteria given the FBO 2030 loading under the 5-year, 4-hour wet weather event are summarized in **Table 5-1**.

Table 5-1. Summary Comparison of One-Plant and Two-Plant Scenario Evaluation Results

Parameter	Value	One-Plant Scenario	Two-Plant Scenario
Annual Average Flow	mgd	18.0	14.8 to Norman WRF 3.2 to North WRF
Maximum Month Flow	mgd	21.6	17.8 to Norman WRF 3.8 to North WRF
Maximum Day Flow	mgd	36.0	29.4 to Norman WRF 6.6 to North WRF
Peak 2-hour Flow	mgd	81.9	64.1 to Norman WRF 17.8 North WRF
Number of predicted locations that have less than one foot of freeboard	-	54	50
Number of predicted SSO locations	-	22	23
Estimated quantity of overflows	MG	0.42	0.45
Recommended length of gravity sewer improvements	mi	12.6	11.8
Number of lift stations that do not meet evaluation criteria	-	0	0
Estimated construction cost for gravity sewer improvements	millions	\$14.0	\$12.7

The recommended improvements for the One-Plant and Two-Plant Scenarios are shown on **Figures 4-3 and 4-15**, respectively.

To ultimately determine whether or not a North WRF should be constructed in the future, more information is needed than that included in this project. Costs for a new North WRF, as well as costs to expand the existing Norman WRF to meet the One-Plant or Two-Plant Scenario predicted influent flow must be considered. Costs and benefits for WRF effluent, both direct non-potable and indirect potable, also need to be considered. There are other economic and non-economic factors that will need to be considered as well to ultimately reach the decision that is best for the City.