



1. Foundation shall comply with current City of Norman Building Code Design.
2. Screening must be built of Masonry.
3. Height of screening shall be 1 foot above height of container with a minimum height of 5 foot.
4. Gates must be opaque and have a permanent hold open device.
5. An unobstructed overhead clearance of 22 feet is required.
6. See Standard GC-04 for turning radii of sanitation vehicles.

SOLID WASTE CONTAINER ENCLOSURE

City Engineer Approval:

CITY OF NORMAN, OKLAHOMA

Approval Date:

Revision Date: 1-12-2001

Rev. No. 0

DRAWING NO. GC 03