



Temporary Heat Checklist

Development Services Division – 225 N. Webster Ave., Norman, OK 73069 – (405) 366-5339

ALL ITEMS BELOW MUST BE COMPLETE TO RECEIVE TEMPORARY HEAT

1.) FURNACE

- A. Clearances from combustibile materials
- B. Access passage way complete

2.) ELECTRIC SUPPLY

- A. Ground wire connected at furnace
- B. Permanent wiring at appliance

3.) VENT

- A. Tee or wye fitting installed high as possible in furnace closet and capped if second appliance not connected
- B. Clearance from combustibile materials

4.) THERMOSTAT

- A. Installed within living area

5.) SUPPLY AIR

- A. Outlets open

6.) RETURN AIR (ALL RETURNS)

- A. Intake open
- B. Dust filter-hog hair or equal

7.) COMBUSTION AIR

- A. Source outside furnace closet

8.) INSIDE GAS

- A. Gas cock outside furnace
- B. Union between gas cock and furnace
- C. Air gauge removed, valve and cap on unused outlets (valves are not required on unused outlets for temporary heat but shall be installed at final inspection)